

CALIFORNIA PUBLIC UTILITIES COMMISSION

Report of Gas Leak or Interruption*

CPUC File No. 420 Initial

Part I: CPUC CONTACT INFORMATION

Operator: Pacific Gas and Electric Co.	CPUC Contact: Name: Incidents & Emergencies	CPUC Website: <input type="checkbox"/>	Recorder <input type="checkbox"/>	Fax <input type="checkbox"/>
Contact Person: Rosa Dueñas	Date: 06/08/2023	Time (24hr): 16:08		
e-mail: R1dj@pge.com	CPUC Information Request: <input type="checkbox"/> Written Report	<input type="checkbox"/> Sketch/Photo	<input type="checkbox"/> FD Report	
Phone: 510/298-7063	DOT Notified: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	DOT Report Number: 1369527/		

Part II: INCIDENT DETAILS

<u>Incident Location</u>	<u>Incident Time (24hr)</u>	<u>Reported to the Operator (24hr)</u>									
City/County: San Jose/Santa Clara Address/Location: 15660 Alum Rock Avenue	Date: 06/08/23 Time: 15:30	Date: 06/08/23 Time: 04:09 Reported by: PG&E Personnel									
<u>Reason(s) for Reporting</u> (check all that apply)											
<u>Gas Leak Associated with</u>		<u>Emergency Action Required</u> <input checked="" type="checkbox"/> None									
<input type="checkbox"/> Death <input type="checkbox"/> OP Condition <input type="checkbox"/> \$\$Damage <input checked="" type="checkbox"/> Injury <input type="checkbox"/> UP Condition <input type="checkbox"/> Media Coverage <input type="checkbox"/> Service Interruption <input type="checkbox"/> Operator Judgment <input type="checkbox"/> Public Attention <input type="checkbox"/> Transmission Line Test Failure <input type="checkbox"/> Required Transmission Line Shutdown		<input type="checkbox"/> Traffic Rerouted <input type="checkbox"/> Area Blocked Off <input type="checkbox"/> Building Evacuated <input type="checkbox"/> Other Emergency actions (describe) <input type="checkbox"/> Release of Gas > 3 MMCF									
<u>Incident Cause</u>		<input type="checkbox"/> Construction Defect									
<input checked="" type="checkbox"/> Material Failure <input type="checkbox"/> Dig In <input type="checkbox"/> Fire/Explosion <input checked="" type="checkbox"/> UNKNOWN - MORE INFORMATION TO FOLLOW <input type="checkbox"/> Corrosion <input type="checkbox"/> Vehicle Impact <input type="checkbox"/> Other (describe):		<input type="checkbox"/> Suicide									
<u>Escaping Gas Involvement</u> (check all that apply)		<input checked="" type="checkbox"/> Leak Only <input type="checkbox"/> Fire <input type="checkbox"/> Explosion									
Summary (Briefly describe the incident and the probable cause): On Thursday, June 8, 2023, at approximately 1530 hours, PG&E Incident on-duty personnel confirmed a release of gas from a pipeline resulted in an injury necessitating in-patient hospitalization (admission & projected overnight stay). The PG&E employee was admitted to the hospital, is in stable condition, was under observation after suffering facial injuries. The injuries occurred while working on a 4-inch steel distribution main and involved the dislodgment of a plug during a scheduled leak repair. Local fire and police department personnel responded, and the employee was transported for treatment in an ambulance. This incident is being reported to the DOT and CPUC due to a release of gas resulting in an injury necessitating in-patient hospitalization (admission & projected overnight stay).											
<u>Gas Equipment Affected</u> (check all that apply)		<u>Specification of Failed Equipment</u>									
<input checked="" type="checkbox"/> Main <input type="checkbox"/> Regulator <input type="checkbox"/> Meter <input type="checkbox"/> Valve <input type="checkbox"/> Service Line <input type="checkbox"/> Controls <input type="checkbox"/> Service Riser <input type="checkbox"/> Customer Facility <input type="checkbox"/> Transmission Line <input checked="" type="checkbox"/> Other (describe): Completion Plug		<input checked="" type="checkbox"/> Steel <input type="checkbox"/> Cast Iron <input type="checkbox"/> Plastic <input type="checkbox"/> Copper <input type="checkbox"/> Other Pipe Size: 4" MAOP: 60psi Operating Pressure: 54psi									
		<u>Injuries and Fatalities</u>									
		<input type="checkbox"/> None <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: center;">Injuries</td> <td style="width: 20%; text-align: center;">Fatalities</td> </tr> <tr> <td>Company</td> <td style="text-align: center;">(1)</td> <td style="text-align: center;">(0)</td> </tr> <tr> <td>Other</td> <td style="text-align: center;">(0)</td> <td style="text-align: center;">(0)</td> </tr> </table>		Injuries	Fatalities	Company	(1)	(0)	Other	(0)	(0)
	Injuries	Fatalities									
Company	(1)	(0)									
Other	(0)	(0)									
<u>Dig-in Information</u>		<u>Estimated Damage</u>									
<input checked="" type="checkbox"/> N/A USA notification required: <input type="checkbox"/> Yes <input type="checkbox"/> No USA notified: <input type="checkbox"/> Yes <input type="checkbox"/> No Facilities properly marked: <input type="checkbox"/> Yes <input type="checkbox"/> No		Name of Excavator: Excavator Contact Person: Phone: ()									
		Damage to gas facilities: \$() Other damage involving: \$() TOTAL: \$()									
<u>Recovery from Incident</u>	<u>Date</u>	<u>Time (24hr)</u>	<u>Public Agencies on Scene</u>	<u>Customer Outage</u>							
☞ Co Personnel on scene:	(06/08)	(3:00)	<input type="checkbox"/> None	<input checked="" type="checkbox"/> None							
Gas flow stopped:	(06/08)	(05:31)	<input type="checkbox"/> Media <input checked="" type="checkbox"/> Police	Customers out of service: ()							
Service restored:	(N/A)	(N/A)	<input checked="" type="checkbox"/> Fire <input checked="" type="checkbox"/> Ambulance	Customer-hours outage: ()							

Part III: CPUC INVESTIGATION

Is further investigation warranted? Yes <input type="checkbox"/> No <input type="checkbox"/>	Signature of CPUC Engineer: _____
Date incident investigated: _____	Field report attached: Yes <input type="checkbox"/> No <input type="checkbox"/>
CPUC Inspector: _____	

* The information contained in this report is provided solely for the confidential use of the Commission and its staff and is not open to public inspection (PUC GO 66-D, Public Utilities Code, Sections 315 and 583)