

The Following information regarding this incident has been reported:

Reporting Date: 1/23/2025 1:31:03 PM

Incident Date: 1/23/2025 @ 8:30 a.m.

Reported By: Paul C. Pimentel, Principal Manager

Utility Name: Southern California Edison Company

Phone Number: (626)302-5830

Email Address: Paul.Pimentel@sce.com

Incident Location: Hueneme Road and Laguna Road Camarillo, Ventura County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Redstone
- Voltage (KV): 16 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report as preliminary information reflects a vehicle struck and damaged a utility pole supporting overhead electrical facilities on the Redstone 16 kV circuit out of Estero Substation which resulted in a circuit relay at 8:33 a.m. Shortly thereafter, a brush fire known as the Laguna Fire reportedly ignited several spans from the location where the pole was damaged. Due to the close-in-time circuit activity and the

reporting of the fire in the vicinity of the involved facilities, we are submitting this report out of an abundance of caution. It is our understanding the Ventura County Fire Department is investigating the incident. The brush fire consumed approximately 50 acres before it was reported that forward progress was stopped. At this time we have no indication that any structures were damaged by the brush fire.