



73233 State Route 70 • Portola, CA 96122
(800) 555-2207 • (530) 832-4261 • Fax (530) 832-5761
www.psrec.coop

Your Touchstone Energy® Cooperative
The power of human connections®



October 29th, 2025

VIA CPUC Docket #EA2025-1253/TA2025-1405/SA2025-1406

California Public Utilities Commission
Electric Safety and Reliability Branch
Safety and Enforcement Division
505 Van Ness Avenue
San Francisco, CA 94102

Re: Electric Substation and Distribution Audit of PSREC

Mr. Tse,

Plumas-Sierra Rural Electric Cooperative (PSREC) has reviewed the California Public Utilities Commission's (CPUC) correspondence dated September 30, 2025, addressing the violations identified during the CPUC audit conducted June 16th through June 20th, 2025.

PSREC appreciates the time and dedication of CPUC staff and values the feedback provided through the Commission's oversight. The Cooperative remains committed to maintaining full compliance with all applicable safety and operational standards, including General Orders (GOs) 95, 128, and 165. PSREC has taken steps to address the identified issues and is implementing preventive measures to ensure continued compliance moving forward.

All violations noted in the audit report were prioritized, with an emphasis on enhanced staff training. PSREC acknowledges the CPUC's concerns regarding records violations and has taken appropriate corrective action. For field inspection violations, work orders were generated for all applicable items, and the necessary repairs have been completed. Visibility strips and high-voltage signs were replaced at each identified location, bird's nests were removed, vegetation was trimmed in areas of concern, and exposed ground wires and damaged ground moldings were repaired. Additionally, new eyewash stations have been ordered for all substations, the distribution transformer fan in Quincy 1 has been fixed, and missing inspection forms have been reposted.

Should you require any additional information or clarification, I can be reached by email at Jason.Harston@psrec.com or by phone at (530) 832-6035.

Respectfully submitted,

A handwritten signature in blue ink, appearing to read "Jason Harston", is written over a light blue circular background.

Jason Harston
Engineering and Operations Manager