

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3298



April 11, 2025

EA2025-1290

Timothy Bass, P.E.
Utilities Engineering Manager
Vernon Public Utilities
4305 Santa Fe Avenue Vernon, CA 90058

Subject: Audit of Vernon Public Utilities

Mr. Bass:

On behalf of the Electric Safety and Reliability Branch of the California Public Utilities Commission (CPUC), James Miller of my staff conducted an electric distribution audit of Vernon Public Utilities (VPU) from February 10-14, 2025. The audit included a review of VPU's records and field inspections of VPU's facilities.

During the audit, my staff identified violations of one or more General Orders (GOs). A copy of the audit findings itemizing the violations is enclosed. Please advise me no later than May 12, 2025, by electronic or hard copy, of all corrective measures taken by VPU to remedy and prevent such violations. Please note that ESRB will be posting the audit report and your response to our audit on the CPUC website. If there is any information in your response that you would like us to consider as confidential, we request that in addition to your confidential response, you also provide us with a public or redacted version of your response that can be posted publicly on our website.

If you have any questions concerning this audit, you can contact James Miller at (213) 660-8898 or James.Miller@cpuc.ca.gov.

Sincerely,

A handwritten signature in blue ink that reads "Fadi Daye". The signature is fluid and cursive, with the first name "Fadi" and last name "Daye" clearly distinguishable.

Fadi Daye, P.E.
Program and Project Supervisor
Electric Safety and Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission

Enclosures: Audit Findings

Cc: Lee Palmer, Director, Safety and Enforcement Division, CPUC
Eric Wu, Program Manager, Safety and Enforcement Division, CPUC
Majed Ibrahim, Senior Utilities Engineer (Supervisor), ESRB, SED, CPUC
James Miller, Utilities Engineer, ESRB, SED, CPUC

AUDIT FINDINGS

I. Records Review

My staff reviewed the following records during the audit:

- Patrol & Detailed Inspection records.
- Late Inspections
- Work Orders Created from Inspections
- Repair Work Orders
- Intrusive Testing Records
- Third Party Notifications
- Pole Loading Calculation Records

II. Records Review – Violations List

My staff observed the following violations during the records review portion of the audit:

GO 95, Rule 18-B1, Maintenance Programs, states in part:

Companies shall undertake corrective actions within the time periods stated for each of the priority levels set forth below. Scheduling of corrective actions within the time periods below may be based on additional factors, including the following factors, as appropriate ...

GO 95, Rule 31.1, Design, Construction and Maintenance, states in part:

For all particulars not specified in these rules, design, construction, and maintenance should be done in accordance with accepted good practice for the given local conditions known at the time by those responsible for the design, construction, or maintenance of communication or supply lines and equipment.

VPU's records indicated that at the end of calendar year 2024, VPU had 20 open overhead work orders that were past VPU's scheduled due date for corrective action.

III. Field Inspections

My staff inspected the following structures during the field inspection portion of the audit:

| No. | Facility Identification | Facility Type | Location |
|-----|-------------------------|---------------|----------|
| 1 | 3976VP | Utility Pole | Vernon |
| 2 | 1869VP | Utility Pole | Vernon |
| 3 | 2941VP | Utility Pole | Vernon |
| 4 | 333396M | Utility Pole | Vernon |
| 5 | 388666M | Utility Pole | Vernon |
| 6 | 436974M | Utility Pole | Vernon |
| 7 | 436974M | Utility Pole | Vernon |
| 8 | 3993VP | Utility Pole | Vernon |
| 9 | 333400M | Utility Pole | Vernon |
| 10 | 337301M | Utility Pole | Vernon |
| 11 | 389902M | Utility Pole | Vernon |
| 12 | 337303M | Utility Pole | Vernon |
| 13 | 337304M | Utility Pole | Vernon |
| 14 | 337305M | Utility Pole | Vernon |
| 15 | 337306M | Utility Pole | Vernon |
| 16 | 337307M | Utility Pole | Vernon |
| 17 | 1043902H | Utility Pole | Vernon |
| 18 | 1493VP | Utility Pole | Vernon |
| 19 | 4670VP | Utility Pole | Vernon |
| 20 | 4677VP | Utility Pole | Vernon |
| 21 | 4678VP | Utility Pole | Vernon |
| 22 | 4679VP | Utility Pole | Vernon |
| 23 | 5204VP | Utility Pole | Vernon |
| 24 | 4875VP | Utility Pole | Vernon |
| 25 | 884407E | Utility Pole | Vernon |
| 26 | 884406E | Utility Pole | Vernon |
| 27 | 884405E | Utility Pole | Vernon |
| 28 | 4268346E | Utility Pole | Vernon |
| 29 | 847856E | Utility Pole | Vernon |
| 30 | 884403E | Utility Pole | Vernon |
| 31 | 4219743E | Utility Pole | Vernon |
| 32 | 4219744E | Utility Pole | Vernon |
| 33 | 2377VP | Utility Pole | Vernon |
| 34 | 2494VP | Utility Pole | Vernon |
| 35 | 2493VP | Utility Pole | Vernon |
| 36 | 2578VP | Utility Pole | Vernon |
| 37 | EV8862 | Utility Pole | Vernon |
| 38 | 2316VP | Utility Pole | Vernon |

| | | | |
|----|----------|--------------|--------|
| 39 | 7447EV | Utility Pole | Vernon |
| 40 | 3436VP | Utility Pole | Vernon |
| 41 | 3435VP | Utility Pole | Vernon |
| 42 | 3434VP | Utility Pole | Vernon |
| 43 | 4903VP | Utility Pole | Vernon |
| 44 | 2371VP | Utility Pole | Vernon |
| 45 | 7225EV | Utility Pole | Vernon |
| 46 | 8381EV | Utility Pole | Vernon |
| 47 | EV8382 | Utility Pole | Vernon |
| 48 | 3262VP | Utility Pole | Vernon |
| 49 | 4446VP | Utility Pole | Vernon |
| 50 | 4445VP | Utility Pole | Vernon |
| 51 | 4444VP | Utility Pole | Vernon |
| 52 | 4443VP | Utility Pole | Vernon |
| 53 | 5326VP | Utility Pole | Vernon |
| 54 | 900345E | Utility Pole | Vernon |
| 55 | 4646VP | Utility Pole | Vernon |
| 56 | 3005VP | Utility Pole | Vernon |
| 57 | 1688VP | Utility Pole | Vernon |
| 58 | 3827VP | Utility Pole | Vernon |
| 59 | 3998VP | Utility Pole | Vernon |
| 60 | 7481VP | Utility Pole | Vernon |
| 61 | 2003VP | Utility Pole | Vernon |
| 62 | 5374EV | Utility Pole | Vernon |
| 63 | 597V | Utility Pole | Vernon |
| 64 | 5080VP | Utility Pole | Vernon |
| 65 | 5099VP | Utility Pole | Vernon |
| 66 | 3052VP | Utility Pole | Vernon |
| 67 | 3053VP | Utility Pole | Vernon |
| 68 | 2572VP | Utility Pole | Vernon |
| 69 | 7016EV | Utility Pole | Vernon |
| 70 | 1524VP | Utility Pole | Vernon |
| 71 | 2039VP | Utility Pole | Vernon |
| 72 | 4138VP | Utility Pole | Vernon |
| 73 | 1387VP | Utility Pole | Vernon |
| 74 | 1969VP | Utility Pole | Vernon |
| 75 | 5513EV | Utility Pole | Vernon |
| 76 | 3629VP | Utility Pole | Vernon |
| 77 | 3632VP | Utility Pole | Vernon |
| 78 | 1261VP | Utility Pole | Vernon |
| 79 | 3195VP | Utility Pole | Vernon |
| 80 | 1776751E | Utility Pole | Vernon |
| 81 | 5165VP | Utility Pole | Vernon |

| | | | |
|-----|--------------------|------------------------|--------|
| 82 | 3704VP | Utility Pole | Vernon |
| 83 | 2275VP | Utility Pole | Vernon |
| 84 | 2111VP | Utility Pole | Vernon |
| 85 | 2112VP | Utility Pole | Vernon |
| 86 | 1498VP | Utility Pole | Vernon |
| 87 | 327V | Utility Pole | Vernon |
| 88 | 4623VP | Utility Pole | Vernon |
| 89 | 4622VP | Utility Pole | Vernon |
| 90 | 4621VP | Utility Pole | Vernon |
| 91 | 4611VP | Utility Pole | Vernon |
| 92 | 4608VP | Utility Pole | Vernon |
| 93 | 4610VP | Utility Pole | Vernon |
| 94 | 4607VP | Utility Pole | Vernon |
| 95 | 3381VP | Utility Pole | Vernon |
| 96 | 4223VP | Utility Pole | Vernon |
| 97 | 4417VP | Utility Pole | Vernon |
| 98 | 3272VP | Utility Pole | Vernon |
| 99 | 3498VP | Utility Pole | Vernon |
| 100 | 4177VP | Utility Pole | Vernon |
| 101 | 3487VP | Utility Pole | Vernon |
| 102 | 3515VP | Utility Pole | Vernon |
| 103 | 3500VP | Utility Pole | Vernon |
| 104 | 3499VP | Utility Pole | Vernon |
| 105 | V0850 | Vault with Gas Switch | Vernon |
| 106 | PM2306 | Padmounted Transformer | Vernon |
| 107 | V0851 | Vault with Gas Switch | Vernon |
| 108 | PM2312 | Padmounted Switch | Vernon |
| 109 | PM2304 | Padmounted Transformer | Vernon |
| 110 | PM2303 | Padmounted Transformer | Vernon |
| 111 | V0849 | Vault with Gas Switch | Vernon |
| 112 | V1157 | Vault with Gas Switch | Vernon |
| 113 | PM2185 | Padmounted Transformer | Vernon |
| 114 | PM1570VP | Padmounted Transformer | Vernon |
| 115 | V1155 | Vault | Vernon |
| 116 | PM1376 | Padmounted Transformer | Vernon |
| 117 | PM2391 | Padmounted Transformer | Vernon |
| 118 | 4925 E. 52nd Place | Vault with Splice | Vernon |
| 119 | V206 | Vault with Gas Switch | Vernon |
| 120 | PM2366 | Padmounted Transformer | Vernon |
| 121 | PM1700 | Padmounted Transformer | Vernon |
| 122 | PM1560 | Padmounted Transformer | Vernon |
| 123 | PM2297 | Padmounted Transformer | Vernon |
| 124 | PM2298 | Padmounted Transformer | Vernon |

IV. Field Inspection Violations List

GO 95, Rule 56.2 Overhead Guys, Anchor Guys and Span Wires, Use, states in part:

Guys shall be attached to structures, as nearly as practicable, at the center of load. They shall be maintained taut and of such strength as to meet the safety factors of Rule 44 .

A VPU down guy wire on each of the following poles was not taut:

- 4219743E
- 327V

A span guy wire between Pole Nos. 4219743E and 4219744E was not taut.

GO 95, Rule 34, Foreign Attachments, states in part:

Nothing in these rules shall be construed as permitting the unauthorized attachment, to supply, street light or communication poles or structures, of antennas, signs, posters, banners, decorations, wires, lighting fixtures, guys, ropes and any other such equipment foreign to the purposes of overhead electric line construction.

Unauthorized foreign attachments were observed on the following poles:

- Pole No. 3434VP supported an unauthorized traffic mirror.
- Pole No. 3381VP supported an unauthorized sign advertising a real estate wholesaler enterprise.
- Pole No. 3381VP supported an unauthorized sign of a service offering to purchase semi trucks.
- Pole No. 337301M supported an unauthorized sign advertising a power washing service.

GO 95, Rule 31.1, Design Construction and Maintenance, states in part:

Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.

The following overhead facilities were in need of maintenance:

- The ground moulding on Pole Nos. 337301M and 337304M was damaged at a height of above eight feet.
- The visibility strips on Pole Nos. 5204VP, 1261VP, and 1776751E were damaged.
- The guy guard on Pole No. 847856E was damaged.

GO 95, Rule 56.4, Clearances, Section D, From Guys or Span Wires, Subsection (2), Passing and Attached to Same Pole, states:

The radial clearance between different guys, different span wires, or different guys and span wires, attached to the same pole shall not be less than 3 inches.

Two VPU down guy wires attached to Pole No. 327V were in contact with a VPU span guy wire attached to the same pole.

GO 95, Rule 51.6, Marking and Guarding, High Voltage Marking of Poles, states in part:

Poles which support line conductors of more than 750 volts shall be marked with high voltage signs. This marking shall consist of a single sign showing the words "HIGH VOLTAGE", or pair of signs showing the words "HIGH" and "VOLTAGE", not more than six (6) inches in height with letters not less than 3 inches in height. A pair of signs may be stacked to a height of no more than 12 inches. Such signs shall be of weather and corrosion-resisting material, solid or with letters cut out therefrom and clearly legible.

"High Voltage" signs on each of the following poles were either missing or damaged:

- 388666M
- 4219743E
- 900345E
- 7481VP

GO 128, Rule 17.1, Design, Construction and Maintenance, states in part:

For all particulars not specified in these rules, design, construction, and maintenance should be done in accordance with accepted good practice for the given local conditions known at the time by those responsible for the design, construction, or maintenance of [the] communication or supply lines and equipment.

The following padmounted equipment was in need of maintenance:

- Padmounted Transformer PM1700 presented with a small patch of corrosion on the interior of its housing.
- The historical high temperature gauge of Padmounted Transformer PM2298 was not functional.