

From: webmaster@cpuc.ca.gov
To: [USRB](#)
Cc: paul.pimentel@sce.com
Subject: Electric Safety Incident Reported- Southern California Edison Company Incident No: 240712-15913
Date: Friday, July 12, 2024 10:17:15 PM

The Following information regarding this incident has been reported:

Reporting Date: 7/12/2024 10:14:11 PM
Incident Date: 7/12/2024 @ 1:30 p.m.
Reported By: Paul C. Pimentel, Principal Manager
Utility Name: Southern California Edison Company
Phone Number: (626)302-5830
Email Address: paul.pimentel@sce.com

Incident Location: Near 39100 Pauba Road Temecula, Riverside County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? Yes

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Chawa
- Voltage (KV): 12 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: () -

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: SCE submits this report as it involves an event that meets the significant public attention and/or media coverage reporting requirement. Preliminary information indicates SCE equipment was involved in the ignition of a brush fire known as the Pauba Fire that consumed approximately 101 acres. Forward progress of the fire was stopped earlier this afternoon and there were no reports of any structures destroyed or damaged. Local media reported two firefighters assigned to the response were taken to Temecula Valley Hospital due to apparent

heat stroke and were in stable condition. The investigation is ongoing.