

**BEFORE THE PUBLIC UTILITIES COMMISSION OF THE
STATE OF CALIFORNIA**

Order Instituting Rulemaking to Examine
Electric Utility De-Energization of Power
Lines in Dangerous Conditions

Rulemaking 18-12-005

**SOUTHERN CALIFORNIA EDISON COMPANY'S (U 338-E) PUBLIC SAFETY
POWER SHUTOFF 2026 PRE-SEASON REPORT**

CLAIRE TORCHIA
WILLIAM YU

Attorneys for
SOUTHERN CALIFORNIA EDISON COMPANY

2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770
Telephone: (626) 302-1634
E-mail: William.Yu@sce.com

Dated: **July 1, 2026**

**BEFORE THE PUBLIC UTILITIES COMMISSION OF THE
STATE OF CALIFORNIA**

Order Instituting Rulemaking to Examine
Electric Utility De-Energization of Power
Lines in Dangerous Conditions

Rulemaking 18-12-005

**SOUTHERN CALIFORNIA EDISON COMPANY’S (U 338-E) PUBLIC SAFETY
POWER SHUTOFF 2026 PRE-SEASON REPORT**

Pursuant to the California Public Utilities Commission’s Decisions (D.) 21-06-014 and D.21-06-034, Southern California Edison Company (“SCE”) hereby submits its Public Safety Power Shutoff (“PSPS”) 2026 Pre-Season Report (Attachment A hereto). SCE also provides the following link to access and download the 2026 Pre-Season Report and its Appendices A through F thereto: <https://on.sce.com/PSPSPreSeasonReporting>

Appendices D, E and F will be filed via mixed media with the Commission’s Docket Office.

Respectfully submitted,

CLAIRE TORCHIA
WILLIAM YU

/s/ William Yu

By: William Yu

Attorneys for
SOUTHERN CALIFORNIA EDISON COMPANY

2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770
Telephone: (626) 302-1634
E-mail: William.Yu@sce.com

Attachment A
2026 Pre-Season Report

TABLE OF CONTENTS

INSTRUCTIONS	2
SECTION I. AUTHORITIES.....	4
SECTION II: COMMUNITY RESOURCE CENTER PLAN.....	5
SECTION III: CRITICAL FACILITIES AND INFRASTRUCTURE PLAN	10
SECTION IV. PSPS EXERCISE REPORTS	13
SECTION VI. NOTIFICATION PLAN	21
SECTION VII. PSPS EVENT LESSONS LEARNED	24
SECTION VIII. HIGH RISK CIRCUITS	25
SECTION IX OTHERS.....	27
APPENDIX.....	29

Instructions

1. Each electric investor-owned utility (IOU) must file and serve its Public Safety Power Shutoff (PSPS) Pre-Season Report no later than July 1 of each year in Rulemaking (R.) 18-12-005 or its successor proceeding.
2. Respondents to the requirements are Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), San Diego Gas & Electric Company (SDG&E), Bear Valley Electric Service (Bear Valley), Liberty Utilities (CalPeco Electric LLC), and PacifiCorp d.b.a. Pacific Power (PacifiCorp) unless indicated otherwise.
3. Parties may file comments on these reports within 20 days after they are filed, and reply comments within 10 days after the final date to file comments.
4. Any files that are required as part of this Pre-Season Report that cannot be accepted through the Commission's e-filing system may be provided via a uniform resource locator (url) link to a publicly available webpage where the files can be accessed and downloaded. Any such files and their associated url links should remain active and unchanged for a minimum of five years.
5. Any confidential documents may be filed via the CPUC Kiteworks under a confidentiality declaration.
6. The reporting period for the required tables is from June 1 of last year through May 31 of current year unless it is specifically stated otherwise in the guidelines or the template.
7. Any plan submitted should have a version number and the date of the last update.
8. To the extent a required item of information is also required to be included in other submissions such as the IOU's Wildfire Mitigation Plan, Post-Season report, AFN plan, the Pre-Season Report may refer to such submissions rather than repeat the same information; such reference must specify, at minimum, the page, section, and line number(s) for where the required information is contained within the submission. In cases where this reference is to data, a summary table of the data shall be provided in the report.
9. For any PSPS exercise report data that is not available at the time of PSPS Pre-Season Report due date, an IOU must request an extension in advance in accordance with the CPUC Rules of Practice and Procedure.
10. Each IOUs should follow the file name convention and syntax below:

 <Proceeding Number><Utility Abbreviation><Year>PSPS Pre-Season Report_<Submission Date>

 <Utility Abbreviation><Year><Plan Name or Document Name><Submission Date>
11. The Pre-Season Report and each Plan should have a table of contents.
12. The required tables should include the minimum fields listed in the template. Additional fields may be added as needed.

13. All tables must be combined into one Excel workbook with different worksheets to differentiate the topics/tables. A template for the required tables is attached in file named Required Pre-Season Tables 05.01.2022. IOUs may provide additional tables as needed.
14. All the submitted documentation including the appendices must be legible and page numbered.
15. The IOUs should include, among other items, in the required plans sufficient information to demonstrate compliance with PSPS guidelines and SED additional requirements.

If there are any questions regarding the template, please [mail to: PSPSReportTemplates@cpuc.ca.gov](mailto:PSPSReportTemplates@cpuc.ca.gov).

Section I. Authorities

All reporting plans concurrently required to be included in the (current year) Pre-Season Report herein, must be produced in a single document submitted by each electric investor-owned utility. Specifically, these include the community resource center plan (A.1, A.3, and A.6), critical facilities plan (B.2), PSPS Exercise Reports (C.2), education and outreach-related surveys and accessibility efforts and associated costs (E.1, E.2 and E.3), and notification plan (I.3). The (current year) Pre-Season Report must also include the following items of information:

- a. Description of lessons learned from past PSPS events, including feedback from impacted customers and stakeholders, and how the electric investor-owned utility has applied such lessons to its current and future efforts in preparation for the upcoming wildfire season.*
- b. Identify circuits at greatest risk of de-energization during the upcoming wildfire season. Include the number of times each circuit was de-energized during the prior four calendar years, and describe all steps toward risk-reduction and de-energization mitigation for each circuit, including specific outreach and education efforts and efforts to identify and provide appropriate resiliency support to customers with access and functional needs on each circuit.*
- c. Annual reports, as applicable, required by Ordering Paragraphs 8, 21, 27, 30, 33, 36, 38, 41, 46, 47, 51, and 57 of D.21-06-014.*

(Decision (D.) 21-06-034; Appendix A at p. A14, Section K-1.)

Section II: Community Resource Center Plan

1. *Each IOU must provide an updated annual Community Resource Centers (CRC) plan as Appendix A. Describe in the plan all the actions the IOUs have taken, are taking, and will take in preparation for potential PSPS events during the upcoming wildfire season; as part of such description, the IOUs should specify lessons learned from past events, and how they are applying those lessons to their current preparations. The IOUs should incorporate and address the following minimum topics in the CRC plan. (D. 21-06-034, Appendix A at p. A14, Section K-1; SED Additional Information.)*
 - a. *CRC objectives (SED Additional Information.)*
 - b. *CRC strategies, actions, and timing (SED Additional Information.)*
 - c. *CRC contracting effort in place to ensure sufficient contracted CRC available during PSPS events (D.21-06-034, Appendix at p. A1, Sections A-2.)*
 - d. *Engagement with local populations on Access and Functional Needs (AFN) needs (D.20-05-051, Appendix at p. 5, Sections d; D.21-06-034, Appendix at p.A1, Section A-3.)*
 - e. *Stakeholder recommendations on AFN needs of services and supplies (D.21-06-034, Appendix at p.A1, Section A-3.)*
 - f. *Criteria used to determine the types of CRCs needed during each event (D.21-06-034, Appendix at p. A1, Sections A-4.)*
 - g. *Services and supplies available at each CRC to customers and AFN populations (D.21-06-034, Appendix at p. A1, Sections A-7; ESRB-8, p.5, Section II.A.)*
 - h. *CRC information transparency and accessibility on PSPS webpage and PSPS advanced notification during event (D.21-06-034, Appendix at p. A1, Sections A-5.)*
 - i. *COVID-19 considerations, (D.20-05-051, Appendix at p. 5, Sections d.)*
 - j. *Prior year CRC usage metrics (D.21-06-034, Appendix at p. A1, Sections A-6.)*
 - k. *CRC program evaluation including customers feedback, CRC related surveys, survey results, survey evaluation, and IOU's related challenges (D.21-06-034, Appendix at p. A1, Sections A-6; SED Additional Information.)*
 - l. *Lessons learned protocol (SED Additional Information.)*
Please incorporate in the above sections how the utility is applying the lessons learned related to CRC in Table 14 of Section VII.

Response: SCE's Community Resource Plan is in Appendix A of this report. Lessons Learned are captured in Table 14 in the PSPS Pre-Season Tables excel workbook in Appendix F.

2. *The IOUs must provide a list of all CRCs available in the IOUs' service territories in advance of wildfire season with the following minimum fields: (ESRB-8, p.5, Section II.2.A;*

D.20-05-051, Appendix at p. 5&6, Sections d; SED Additional Information.)

Table 1 – List of Available Community Resource Centers (as of cut off date of current year)

- a. CRC Unique ID*
- b. Location Name*
- c. County or Tribe*
- d. CRC Type (e.g., fixed facility or mobile location, indoor or outdoor, tent, micro, mobile)*
- e. Standard Operation Hours*
- f. List of Planned Supplies**
- g. List of Planned Services**
- h. List of Planned AFN Services and Supplies**
- i. Contracted (Yes or No)*
- j. Date of Contract*
- k. Location Address*
- l. Latitude (with at least five digits after decimal point)*
- m. Longitude (with at least five digits after decimal point)*

** Sub-table(s) may be provided for the Lists.*

Response: SCE's list of available Community Resource Centers (CRCs) is in Table 1 of its PSPS Pre-Season Tables in Appendix F.

3. *The annual CRC plan must detail how the utility will provide the services and supplies required to serve Medical Baseline (MBL) and AFN populations as recommended by regional local government, Advisory Boards, public safety partners, representatives of people/communities with access and functional needs, tribal representatives, senior citizen groups, business owners, community resource organizations, and public health and healthcare providers. In the annual CRC plans, the utilities must set forth the specific recommendations made by the above-noted entities, whether the utilities adopted the recommendation (or did not adopt the recommendation), the reason it was adopted (or not adopted), and the timeline for implementation. The IOUs must provide a summary table of stakeholder recommendations on AFN needs for services and supplies including, at a minimum, the following fields: (D.21-06-034, Appendix at p.A1, Section A-3; SED Additional Information.)*

Table 2 - Stakeholders' CRC Recommendations on AFN Needs

- a. Recommendation Description*
- b. Recommended Date*

- c. Recommending Party Type (e.g., tribal, local government, non-profit entity, Advisory Boards, public health and healthcare provider)*
- d. Adopted? (Yes or No)*
- e. Reasoning for Adoption/Denial*
- f. Initiative(s) As a Result of Recommendation*
- g. (Estimated) Planning Start Date*
- h. (Estimated) Organization Completion Date*
- i. (Estimated) Equipment Completion Date*
- j. (Estimated) Training Completion Date*
- k. (Estimated) Exercise Completion Date*

If an adopted recommendation is not completed in the current reporting period, it should be carried into future annual reporting period(s) until it is finished or no longer relevant.

Response: Stakeholders' CRC Recommendations on AFN needs are in Table 2 of the PSPS Pre-Season Tables in Appendix F.

4. *The IOU CRC plan must include prior year CRC usage metrics including, at a minimum, the following fields: (D.21-06-034, Appendix at p. A1, Sections A-6.)*

Table 3 – Prior Year PSPS CRC Usage Metrics

- a. Event ID*
- b. Event Name/Period (PSPS Event Name will match the same event name used during the event and shared with public safety partners)*
- c. County*
- d. Date Service Area De-energized*
- e. Time Service Area De-energized (24-hr. clock)*
- f. Date CRC Opened*
- g. Time CRC Opened*
- h. Date Service Area Re-energized*
- i. Time Service Area Re-energized (24-hr. clock)*
- j. Date CRC Closed*
- k. Time CRC Closed*
- l. Total Days Opened Total Hours Opened (Integer)*
- m. Type of CRC (Indoor, Outdoor, Mobile)*
- n. Average AQI during Operation*
- o. Was CRC powered by Backup Generation? (yes/no)*

- p. Operation Hour Compliance Indicator (Yes or No, if CRC was operable at least 8 AM-10 PM during an active de-energization event)*
- q. If Not in Compliance with Operation Hour Requirements, Provide an Explanation*
- r. Service or Supply Provided (List the name of each service or supply provided by the utility in a separate field and fill the description in the cell such as Bottle Water “Yes”, Charging Station “Yes”, Cellular Network Services “Yes”, Chairs “Yes”, PSPS Information Representatives “Yes”, Restrooms “Yes”, ADA Accessible “Yes”)*
- s. Total Number of Visitors*
- t. Location Address*
- u. Latitude (with at least five digits after decimal point)*
- v. Longitude (with at least five digits after decimal point)*

Response: SCE’s prior year CRC usage metrics are in Table 3 of its PSPS Pre-Season Tables in Appendix F.

5. *The IOU CRC plan must include a prior year CRC customer feedback summary including, at a minimum, the following fields: (D.21-06-034, Appendix at p. A1, Sections A-6; SED Additional Information.)*

Table 4 - Prior Year CRC Customer Feedback

- a. Customer Feedback Type (e.g. resource availability, operation hour, location, customer service, complaints)*
- b. Customer Feedback Description/ Open Comments on Areas in Need of Improvement*
- c. Feedback Submission Count (for this feedback type)*
- d. Initiative(s)/Responsive Action(s) – List the initiatives to respond to feedback if any. If there is none, please explain.*
- e. Initiative Implementation Start Date*
- f. Initiative Estimated Completion Date*
- g. Implementation Status as of DD/MM/YYYY (Planning, Implementing, or Complete)*

Response: SCE’s prior year CRC customer feedback is in Table 4 of its PSPS Pre-Season Tables in Appendix F.

6. *The IOU CRC plan must include prior year CRC challenges faced when setting up and*

operating CRCs. The challenge summary includes, at a minimum, the following fields: (D.21-06-034, Appendix at p. A1, Sections A-6.)

Table 5 - Prior Year IOU CRC Challenges

- a. Challenge Type*
- b. Description of Challenge*
- c. Initial Month and Year Challenge Discovered*
- d. Initiative(s)/Responsive Action(s) – List the responsive initiatives to address the challenge if any. If there is none, please explain.*
- e. Implementation Start Date*
- f. Estimated Completion Date*
- g. Implementation Status As of MM/DD/YYYY (Planning, Implementing, or Complete)*

Response: SCE's prior year CRC challenges are in Table 5 of its PSPS Pre-Season Tables in Appendix F.

Section III: Critical Facilities and Infrastructure Plan

1. *Each IOU must provide an updated Critical Facilities and Infrastructure (CFI) plan as Appendix B. Describe in the plan all the actions the IOUs have taken, are taking, and will take in preparation for potential PSPS events during the upcoming wildfire season; as part of such description, the IOUs should specify lessons learned from past events, and how they are applying those lessons to their current preparations. The IOUs should incorporate and address the following minimum topics in the CFI plan. (D. 21-06-034, Appendix A at p. A14, Section K-1; SED Additional Information.)*
 - a. *CFI objectives (SED Additional Information.)*
 - b. *CFI strategies, actions, and timing (SED Additional Information.)*
 - c. *CFI definition and IOU CFI contact on PSPS website (D.21-06-034, Appendix at p. A3, Sections B-1.)*
 - d. *Identification method of CFI (D.21-06-034, Appendix at p. A3, Sections B-2; D.19-05-042, Appendix p.A11.)*
 - e. *Changes in CFI since prior annual report (D.21-06-034, Appendix at p. A3, Sections B-2.)*
 - f. *Maintenance and update process of CFI list (D.21-06-034, Appendix at p. A3, Sections B-2), (D.21-06-014, Ordering Paragraph 21, D.19-05-042, Appendix p.A11-12.)*
 - g. *Collaboration with transmission-level customers (D.21-06-034, Appendix at p. A3, Sections B-2.)*
 - h. *Comparison of current year CFI request total with last year (D.21-06-034, Appendix at p. A3, Sections B-2.)*
 - i. *CFI backup power assessment efforts/actions, backup power provisions and terms (D.21-06-034, Appendix at p. A3, Sections B-2; D.21-06-014, Ordering Paragraph 21; D.21-06-014, Ordering Paragraph 57; D.19-05-042, Appendix p.A12.)*
 - j. *Engagement with local government and public safety partners on CFI identification and back-up generation need (D.20-05-051, Appendix at p. A7, Sections (f).)*
 - k. *Maintenance and accessibility of CFI list (D.21-06-034, Appendix at p. A3, Sections B-3.)*
 - l. *Consultation with local and tribal governments (D.21-06-034, Appendix at p. A3, Sections B-3.)*
 - m. *Coordination with CFI to maintain energization during PSPS events of varying lengths (D.19-05-042, Appendix at p.A12.)*
 - n. *Lessons learned protocol, including where in the plan you have incorporated in any lessons learned.*

Please include the lessons learned related to CRC in Table 14 of Section VII.

Response: SCE's Critical Facilities and Infrastructure Plan is in Appendix B of this report. Lessons Learned are captured in Table 14 in the PSPS Pre-Season Tables in Appendix F.

2. *The IOUs must include a list of critical facilities and infrastructure within the utility's service area. The list must include, at a minimum, the following fields. The list must be posted in the IOUs' PSPS web portal with restricted access to confidential information. (D.21-06-034, Appendix at p. A3-4, Sections B-1 and B-3; D.21-06-014, Ordering Paragraphs 21, 30, 33 & 57.)*

Table 6 - Critical Facilities and Infrastructure List (as of last updated date)

- a. *Facility/Infrastructure Name*
- b. *CFI Type*
- c. *CFI Address*
- d. *County*
- e. *Date Identified as CFI*
- f. *Primary Point of Contact Name*
- g. *Primary Point of Contact Title*
- h. *Primary Contact Phone Number*
- i. *Primary Contact Email Address*
- j. *Secondary Point of Contact Name*
- k. *Secondary Point of Contact Title*
- l. *Secondary Contact Phone Number*
- m. *Secondary Contact Email Address*
- n. *Last Date of Update on Contact Information**
- o. *Indicator if CFI has been contacted with backup power needs**
- p. *Date of Contact**
- q. *Indicator if CFI has been assessed with backup power needs (Yes or No)**
- r. *Date of Assessment**
- s. *Results of Assessment**
- t. *Whether or not CFI provided any needed backup power generation (Yes or No)**

**These fields are applicable to PG&E, SCE, and SDG&E only.*

Response: SCE's Critical Facilities and Infrastructure List contains confidential information. As such, SCE has designated this table as confidential consistent with

CPUC guidelines and SED instructions for this report. Due to the confidential nature of this information, Table 6 is not included in the public version of Appendix F.

As part of its annual communication, SCE contacts CFI customers to determine whether they have backup generation. Accordingly, Table 6 indicates whether SCE contacted the CFI customer in its annual communication (Column O) and the date of that communication (Column P). If a CFI customer requests backup generation, SCE provides contact information for a third-party rental vendor.

In addition to this, SCE identified a small number of K-12 public schools that have been disproportionately impacted by PSPS in prior years, and has contacted those schools with an offer to provide temporary backup generation for the 2026 PSPS season. As of the time of this report, temporary generators are already installed at some schools.

3. *The IOUs must include, in the CFI plan, the number of requests from customers to be designated as critical facilities and infrastructure in the current year and the prior year, whether the utility accepted or denied the request, and the reasons for any denial. The list must include the following minimum fields. (D.21-06-034, Appendix at p. A3, Sections B-2.)*

Table 7 – List of Requests to Be CFI Over Last Two Years

- a. *Facility/Infrastructure Type*
- b. *Facility/Infrastructure Location (The city where the CFI customer is located in.)*
- c. *Date of Request*
- d. *Accepted or Denied?*
- e. *Reason for Denial*

Response: SCE did not receive any requests from customers to be designated as critical facilities and infrastructure in the past two years and as such SCE marked ‘not applicable’ in Table 7 in its PSPS Pre-Season Tables in Appendix F.

Section IV. PSPS Exercise Reports

1. *Each investor-owned utility must prepare and file a PSPS Exercise Report as part of the 2026 Pre-Season Report. These PSPS Exercise Reports must include, at a minimum, provisions for both table-top (TTX) and functional PSPS exercises (FSE), how many PSPS exercises were held, the dates held, and what entities participated. Please provide the following tables with the minimum fields listed. (D.21-06-034, Appendix at p. A1, Sections C-2; SED Additional Information.)*

Table 8 - PSPS Exercise Summary (January 1 through December 31 of current year)

1. *Starting Date of Exercise*
 - a. *Ending Date of Exercise*
 - b. *Total Hours of Exercise*
 - c. *Type of Exercise (e.g., table-top, functional, full-scale, and specify if virtual, in-person, or hybrid)*
 - d. *Region (if applicable)*
 - e. *Counties*
 - f. *Number of utility personnel participating in the exercise*
 - g. *Number of public safety partners actively participating as a player in the exercise*
 - h. *Number of AFN community representatives participating as a player in the exercise*
 - i. *Total Number of Participants*

Table 9 - List of Exercise Participated Entities

- a. *Name of Entity*
- b. *Exercise Date Range*

Response: SCE's PSPS exercise summary and list of exercise participant entities for 2026 is in Table 8 and Table 9 of the PSPS Pre-Season Tables excel workbook in Appendix F.

2. *For each exercise, please provide the items below. (SED Additional Information.)*
- a. *After-Action Report*
 - b. *Provide a short general description of the written materials (e.g., slides, instructions) provided to telecommunication carriers and other public safety partners during and after they participate in TTXs, FSEs or other trainings/briefings?*
 - c. *Provide a list that includes the file or document name (if needed a short description), and copies of the written material and/or weblinks to where copies can be found.*

- d. *Indicate if this information is also posted in your public safety partner portal.*

Response:

Please see SCE's response below:

- a) Please see Appendix D for SCE's After Action Report.
- b) SCE provided participants with the following documents during or after SCE's Tabletop Exercise and Functional Exercise: situation manuals, exercise plans, player briefings and exercise decks.
- c) Materials are provided in Appendix D.
- d) Training materials are not posted onto SCE's PSP Portal but public safety partners observing the exercise are able to follow along during the exercises on the portal.

Section V. Education and Outreach

1. *Each utility must conduct, at a minimum, two PSPS education and outreach surveys accessible to all customers each calendar year. The Commission's Safety and Enforcement Division is authorized to direct an IOU to modify or issue more of these surveys. Please provide a survey summary table with the following minimum fields. (D.21-06-034, Appendix at p. A7, Sections E-1; SED Additional Information.)*

Table 10 – Survey Summary (Reporting period for this table is prior calendar year)

- a. *Period Survey Conducted*
- b. *Overall Objectives*
- c. *Surveyed Scope (e.g., pre-season, during-season, post-season, all)*
- d. *Methods (e.g., online, text messages, letter, telephone, in-person)*
- e. *Target Audiences (e.g., residential customer, commercial, CFI, AFN)*
- f. *Total Number of Surveys Sent*
- g. *Total Number of Survey Responses Received*
- h. *Indicate if the survey was conducted in all “prevalent” languages, as defined in D.20-03-004*
- i. *If so, please list the number of “prevalent” languages used during survey*
- j. *If not, please provide an explanation*

Response: SCE's survey summary is in Table 10 of its PSPS Pre-Season Tables in Appendix F.

2. *The IOUs must provide copies of all prior year PSPS education and outreach surveys templates. (D.21-06-034, Appendix at p. A7, Sections E-1; SED Additional Information.)*

Response: A copy of the survey used for the Pre and Post PSPS education and outreach surveys is provided in Appendix E.

3. *Each IOU must collaborate with relevant community-based organizations and public safety partners to develop these surveys, which must include, at a minimum, metrics to evaluate whether the education and outreach is effectively helping communities and residents before, during, and after a PSPS event to plan for alternatives electricity arrangements and/or avoid the impacts of de-energization events. (D.21-06-034, Appendix at p. A7, Sections E-1.)*

Response: In compliance with D.20-03-004, in 2020, the three major California IOUs developed nearly identical survey instruments and a comparable methodology to administer the Pre-/Post- questionnaires in English and prevalent non-English

languages – and to include metrics to evaluate communications effectiveness as described above. In July 2020, prior to launch, the survey plan was presented in a formal open review meeting which included CBOs, public safety partners and others to provide input and approval. SCE has continued to use the same survey instruments because the survey must remain consistent over time in order to track year-over-year changes.

4. *IOUs must include the results of the most recent education and outreach surveys not yet previously reported on, as an attachment to the [current year] Pre-Season Report and the [prior year] Post-Season Report. (D.21-06-034, Appendix at p. A7, Sections E-1.)*

Response: Results of the Residential and Business 2025 Pre/Post research/surveys are included in Appendix E.

5. *IOUs must identify and describe any new PSPS preparedness initiatives/actions in responding to the education and outreach survey results including, but is not limited to, the survey key findings, the survey result recommendations, and the significant unfavorable items. (D.19-05-042, Appendix A p.A24; SED Additional Information.)*

Response: No new PSPS preparedness initiatives/actions have been identified through the surveys in 2025.

6. *Each IOU must report prior year costs for PSPS-related education and outreach in the format of the SED POSTRS3 Template 2021, or reference it if it has been provided in the prior post-season report. (D.21-06-034, Appendix at p. A7, Sections E-3 and K-1)*

Response: SCE provided prior year costs for PSPS-related education and outreach in its 2025 Post-Season Report.¹

7. *PG&E, SCE, and SDG&E are required to describe how it works, in advance of each wildfire season and during each wildfire season, with local jurisdictions, in a proactive manner, to identify and communicate with all people in a de-energized area, including visitors. This requirement is applicable to PG&E, SCE, and SDG&E only. (D.21-06-014, Ordering Paragraph 38.)*

Response:

¹ See

https://edisonintl.sharepoint.com/:x:/r/teams/Public/Misc/_layouts/15/Doc.aspx?sourcedoc=%7B02A3FFE5-DB98-437B-AD88-703A175F8B59%7D&file=SCE_POSTSR3_3-2-2026.xlsx&action=default&mobileredirect=true

SCE works proactively with local jurisdictions in advance of and throughout wildfire season to identify and communicate with all individuals located within a potential de-energized area, including residents, businesses, and visitors, in accordance with D.21-06-014, Ordering Paragraph (OP) 38.

Pre-Wildfire Season Coordination:

SCE conducts outreach to city, county, and tribal government leaders requesting updates to jurisdictional emergency contact information. These communications are delivered via email and include the PSPS Resource Guide, which provides critical preparedness information for local leaders, including:

- Access and Functional Needs (AFN) population considerations
- Community Resource Center (CRC) locations and service
- Outage Map and address lookup tools
- PSPS decision-making process overview
- SCE PSPS website and customer resources

In addition to written outreach, SCE conducts pre-season briefings with High Fire Risk Area (HFRA) jurisdictions to review PSPS program elements, including processes, procedures, roles and responsibilities, and available communication tools to support local coordination.

In-Season Communication and Coordination:

During wildfire season and potential PSPS events, SCE provides ongoing updates to local jurisdictions and the public through multiple communication channels. These include the SCE Outage Map and mobile application, as well as direct email notifications to government stakeholders.

These communication efforts enable local jurisdictions to maintain situational awareness and support outreach to affected populations within their communities, including visitors and transient individuals in de-energized areas.

8. *Each IOU must file information pertaining to, at a minimum, discussions at Working Group meetings regarding the accessibility of the utility's education and outreach efforts, including surveys, for individuals with access and functional needs, the recommendations, if any, made by individuals with or representatives of communities with access and functional needs to enhance education and outreach pertaining to PSPS events, and whether those recommendations, if any, were incorporated into the utility's PSPS protocols. (D.21-06-034, Appendix at p. A7, Sections E-2.)*

Table 11 - AFN Outreach Recommendations

- a. Recommendation Type*
- b. Description of Recommendation*
- c. Party Name*

- d. Date of Recommendation*
- e. Incorporated into PSPS Protocols? (Yes or No)*
- f. Reason for Decision Made*
- g. Description of PSPS Protocol Change*

Response: SCE's AFN Outreach Recommendations are in Table 11 of its PSPS Season Tables in Appendix F.

9. *PG&E, SCE, and SDG&E must include a detailed summary to substantiate all efforts to develop and implement, in advance of wildfire season, a communications strategy to rely on during a proactive de-energization when restrictions due to the power loss exist. This detailed summary must address how the utility worked in coordination with public safety partners to develop this communication strategy. (D.21-06-014, Ordering Paragraph 41.)*

Response:

In 2026, SCE continues to partner with multiple agencies and organizations to educate, provide outreach, obtain feedback, and develop solutions to customer concerns related to PSPS. In April 2026, SCE sent a PSPS Resource Guide to all local and tribal governments in HFRA. The resource guide provides a way for these entities to provide feedback on important PSPS issues such as the AFN Plan and locations for CRCs and CCVs.

Additionally, the guide includes information on tools and resources for local and tribal governments to plan for and respond to PSPS events. SCE also shares an update on its WMP Activities and provides information on customer PSPS mitigation programs. Recipients are requested to share the information with residents and businesses in their community. SCE also offers to meet with recipients to review the material and solicit feedback. Another tool SCE uses to inform local and tribal governments in 2026 is the All-Hazards Emergency Planning meeting. This meeting was held twice (once in person and once online). The meeting covered SCE's PSPS Plan, wildfire mitigation plans, All Hazards Plan and Energy Emergency Alert Program (EEAP) plan.

Invitations were sent to over 3,000 individual email addresses across our service area. A total of 124 external stakeholders (including emergency management partners) attended the meeting on either March 26th or April 9th, 2026.

In April and May 2026 SCE hosted its annual Critical Facility and Critical Infrastructure workshops for customers in the nine sectors. Customers were provided with information on how to prepare for the upcoming wildfire season and how to be resilient and prepared for power outages. The nine sectors are:

1. Emergency Services

2. Government Facilities
3. Health Care and Public Health
4. Energy Sector
5. Water and Wastewater
6. Communications
7. Chemical
8. Transportation
9. Food and Agriculture

10. *PG&E, SCE, and SDG&E must provide all methods used to promote operational coordination with public safety partners. (D.21-06-014, Ordering Paragraph 47.)*

Response:

During PSPS activations, SCE hosts daily calls with county operational areas and critical infrastructure customers. SCE also participates in calls organized by county operational areas as requested. SCE also sends surveys to Public Safety Partners and Critical Infrastructure Customers after PSPS events. Also, during events, all Public Safety Partners provide 24/7 contact information for SCE personnel. SCE's Local Public Affairs staff that are pre-assigned to each city are available for coordination as needed during all events. Upon request, SCE will also meet with local and tribal government officials after PSPS events.

11. *PG&E, SCE, and SDG&E must provide all methods used to work with public safety partners to improve responses to concurrent emergencies. (D.21-06-014, Ordering Paragraph 51.)*

Response:

If during a PSPS outage, there is an additional emergency occurring at the same time (e.g., wildfires, capacity events), SCE works with Public Safety Partners to improve the response to concurrent emergencies by doing the following:

Incident Command System (ICS), Standardized Emergency Management System (SEMS) and National Incident Management System (NIMS) protocols: These guidelines are national standardized emergency management protocols to manage concurrent emergencies. This includes coordinating with appropriate incident leaders through a chain of command during events and managing existing lines of communication through dedicated Agency Representatives and other channels. This may include conducting live calls to Public Safety Answering points (PSAP) or dispatch centers upon activation of SCE's Emergency Operations Center (EOC); hosting daily Systemwide Cooperators Calls, where all Public Safety Partners in the service territory are invited to join and hear the latest event information; and embedding with local or state OES agencies or having agencies embedded in SCE EOC as circumstances warrant. SCE Agency Representatives who engage with Public Safety Partners receive regular training and are well versed in emergency management

systems.

Fire Agency Management: Provides liaison to fire agencies during wildland fire incidents by responding to field incident command posts and serving as the SCE subject matter expert for the fire IMT, coordinating SCE access and ensuring powerline safety measures are in place for first responders, the public and SCE employees.

Direct Engagement: SCE uses the personnel from across SCE territory. SCE also coordinates meetings on emergency plans with Public Safety Partners and facilitates SCE EOC tours to support coordination with Public Safety Partners.

Situational Awareness Sharing: SCE shares consolidated All Hazards Planning meetings to engage in direct discussion with emergency operations the following situational awareness tools with our public safety partners:

- ALERT Wildfire HD Cameras (Home | ALERT Wildfire)
 - SCE Weather Station Data
 - Temperature
 - Dew Point
 - Wind Speed
 - Wind Gust
 - Wind Direction
 - Relative Humidity
- Websites:
 - PSPS Public Safety Partner Portal (<https://publicsafetyportal.sce.com>)
 - SCE PSPS Weather Awareness (SCE Weather Awareness)
 - Consolidated Outage Map (Power Outage Awareness Map | Outage Center Home SCE)

SCE exercised its response to concurrent emergencies on June 2-5, 2026 as part of the annual PSPS Functional Exercise.

Section VI. Notification Plan

1. *Each IOU must provide an updated annual PSPS notification plan as Appendix C. Describe in the plan all the actions the IOUs have taken, are taking, and will take in preparation for potential PSPS events during the upcoming wildfire season; as part of such description, the IOUs should specify lessons learned from past events, and how they are applying those lessons to their current preparations. The IOUs should incorporate and address the following minimum topics in the notification plan. (D. 21-06-034, Appendix A at p. A14, Section K-1; D.21-06-034, Appendix at p. A11, Section H-1 through Section H-9; D.21-06-014, Ordering Paragraph 41; SED Additional Information.)*
 - a. *Notification objectives*
 - b. *Notification strategies, actions, and timing*
 - c. *Notification process planning and improvement*
 - d. *Updated/Current Notification script and templates*
 - e. *In-language translations*
 - f. *Notification methods*
 - g. *Meeting notification timeline requirements*
 - h. *Notification accuracy and precision*
 - i. *Entity responsible for notifications*
 - j. *Consistency of PSPS notification information across all platforms*
 - k. *Coordination with stakeholders*
 - l. *Affirmative notifications to MBL populations and any self-identified vulnerable populations*
 - m. *Notification strategies on AFN population subsets, and the planning, organization, equipment required, training, and exercise for AFN subset notification plans listed on Table 13*
 - n. *Public warning of PSPS events such as week-ahead forecasts*
 - o. *Notification cancellation*
 - p. *Transmission-level customers notification*
 - q. *Impacted customer information available to public safety partners from outset of PSPS*
 - r. *Secure portal for public safety partners*
 - s. *Lessons learned protocol*

Please include the lessons learned related to notification in Table 14 of Section VII.

Response: SCE's Notification Plan is in Appendix C of this report. Lessons Learned are

captured in Table 14 in the PSPS Pre-Season Tables in Appendix F.

2. *Each electric investor-owned utility must develop a notification plan jointly with Cal OES, public safety partners, county, tribal, and local governments, independent living centers, paratransit agencies, durable medical equipment vendors, agencies that serve individuals who receive Medi-Cal home and community-based services, and other organizations representative of all subsets of people or communities with access and functional needs. Each electric investor-owned utility must specifically describe its plans for notifications according to specific access and functional needs, for instance, the needs of persons with vision impairments as distinct from the needs of persons with a developmental disability. Each electric investor-owned utility must finalize its notification plan for inclusion in its [current year] Pre-Season Report. Provide a list of the joint efforts to develop the AFN population notification plan with the aforementioned stakeholders. The table should include the following minimum fields. (D.21-06-034, Appendix at p. A11, Sections H-3.)*

Table 12 - List of Joint Efforts on AFN Notification Plan

- a. *Date of Joint Effort*
- b. *Participant Type*
- c. *Participant Name*
- d. *AFN Subsets or Topics Discussed*
- e. *Result/Proposal*

In addition, IOUs provide a list of AFN population subsets and notification plans including the following minimum fields. Planning, Organization, Equipment, Training, and Exercise (POETE) dates will align with Fiscal Year activities.

Table 13 AFN Population Subset Notification Plan (as of cutoff date)

- a. *AFN Population Type (e.g. vision impairment, developmental disability, older adult, children, limited English proficiency)*
- b. *Subset Notification Plan*
- c. *(Estimated) Planning Start Date*
- d. *(Estimated) Organization Completion Date*
- e. *(Estimated) Equipment Completion Date*
- f. *(Estimated) Training Completion Date*
- g. *(Estimated) Exercise Completion Date*
- h. *# of People Planned to Be Trained on AFN Notification Plan (during reporting period)*
- i. *# of People Trained on AFN Notification Plan (during reporting period)*
- j. *List Types of Training on AFN Notification Plan*

Response: SCE's list of joint efforts on the AFN notification plan is in Table 12 of its PSPS Pre-Season Tables in Appendix F. In addition, SCE's list of AFN population

subsets and notification plans are in Table 13 of its PSPS Pre-Season Tables in Appendix F

3. *PG&E, SCE, and SDG&E must include a detailed summary of efforts to develop, in advance of wildfire season, notification and communication protocols and systems to reach all customers and communicate in an understandable, accessible manner. This detailed summary must include, at a minimum, an explanation of the actions taken by the utility to ensure customers understand (1) the purpose of proactive de-energizations, (2) the process relied upon by the utility for initiating a Public Safety Power Shutoff (PSPS) event, (3) how to manage safely through a PSPS event, and (4) the impacts on customers when a proactive power shutoff is deployed by the utility. This requirement is applicable to PG&E, SCE, and SDG&E only. (D.21-06-014, Ordering Paragraph 41.)*

Response: SCE's detailed summary of efforts to develop pre-season notification and communication protocols, including systems and actions to reach customers in an understandable and accessible manner, is provided in Appendix C – Notification Plan. This appendix describes SCE's notification strategies, customer outreach, communication channels, accessibility measures, and notification templates used to support customer awareness before, during, and after PSPS events.

Section VII. PSPS Event Lessons Learned

1. *IOUs must provide a list of all lessons learned from past PSPS events, including feedback from impacted customers and stakeholders, and explain how the IOU has applied such lessons to its current and future PSPS activities. (D.21-06-034, Appendix at p. A14, Sections K-1.)*

Table 14 – PSPS Event Lessons Learned Summary

- a. Type of Issue (e.g., CRC, notification)*
- b. Description of Issue*
- c. Date of Discovery/Applicable Activation*
- d. Risk Priority (high, medium, low)*
- e. Overall Resolution (Explanation of how IOU has applied lessons learned to its current and future PSPS activities, including any updates to specific plans)*
- f. Responsive Actions (in detail)*
- g. Reference specific Plan page number(s) and updates from lessons learned, if applicable*
- h. Implementation Start Date*
- i. Estimated Completion Date*
- j. Status of Action (e.g., Planning, Implementing, or Complete (if Complete, add Date Complete))*

If a responding action is not completed by the reporting cutoff date, it should be carried into future annual reporting period(s) until it is fully implemented or irrelevant.

Response: SCE outlines lessons learned in each PSPS post-event report, if applicable. Details of the lessons learned are outlined in Table 14.

Section VIII. High Risk Circuits

1. *IOUs should describe the methodology and criteria used to identify circuits at greatest risk of PSPS in the upcoming wildfire season. (D.21-06-034, Appendix at p. A14, Sections K-1.b SED Additional Information)*

Response:

This table lists SCE circuits from 2022-present that were de-energized in three or more PSPS events in 2025 and at least one de-energization during an activation in the prior year, 2024. Because weather is extremely variable and difficult to predict in the medium to long term, along with other exogenous factors, SCE reviewed historical PSPS events as an indicator of future risk to identify High Risk Circuits in Table 15 in the attached PSPS Pre-Season Tables. While this represents SCE’s best estimate of potential high-risk circuits, PSPS events are driven by local weather patterns and fuel conditions that cannot be predicted year-over-year. Weather and fuel conditions can vary drastically year-over-year, causing differences in the frequency, intensity, duration, and location of PSPS events.

2. *IOUs must include the number of times each circuit was de-energized during the prior four calendar years, and describe all steps toward risk-reduction and de-energization mitigation for each circuit, including specific outreach and education efforts and efforts to identify and provide appropriate resiliency support to customers with access and functional needs on each circuit. (D.21-06-034, Appendix at p. A14, Sections K-1.b; SED Additional Information.)*

Table 15 – High Risk PSPS Circuits (as of date of last update)

- a. *Circuit ID*
- b. *Circuit Name*
- c. *Segment ID (optional field)*
- d. *Segment Name (optional filed)*
- e. *Indicator for Distribution Line or Transmission Line*
- f. *Number of Times De-energized (in last four calendar years)*
- g. *Total MBL Customers*
- h. *Total AFN Customers (including MBL)*
- i. *Total CFI*
- j. *Total Customers*
- k. *Steps Toward Risk-reduction and PSPS Mitigation (including effect of PSPS mitigation/risk-reduction on PSPS thresholds or the change in expected de-energizations per year, specific outreach and education efforts, and efforts to identify and provide appropriate resiliency support to customers with access and functional needs on each circuit)*
- l. *Start Date of Step Implementation*

m. Estimated Completion Date

Response: SCE included a list of high-risk PSPS circuits in Table 15 of its PSPS Pre-Season Tables in Appendix F. These circuits were identified based on the methodology described in question 1 above.

Specific outreach and education efforts, and efforts to identify and provide appropriate resiliency support to customers with access and functional needs available to customers in HFRAs are documented in SCE's 2026 AFN Plan.²

² Available at <https://www.sce.com/sites/default/files/outage-safety/R1812005-SCE%202026%20Plan%20to%20Support%20Access%20and%20Functional%20Needs%20Population%20during%20PSPS.pdf>

Section IX Others

Section IX requirements are applicable to PG&E, SCE, and SDG&E only.

1. *PG&E, SCE, and SDG&E must provide, with the following minimum fields, the dates/times when the Joint Utility Public Safety Power Shutoff Working Group (JUPSPSWG) convened and the webpage links to all meeting reports filed with the Commission. (D.21-06-014, Ordering Paragraph 8)*

Table 16 – JUPSPSWG Meetings

- a. *Date of Meeting*
- b. *Time of Meeting*
- c. *Report Name*
- d. *Webpage Link to Report*

Response: SCE includes JUPSPSWG meeting information in Table 16 of its PSPS Pre-Season Tables in Appendix F.

2. *PG&E, SCE, and SDG&E must identify the status of the list of public safety partners, including the last date updated, on their Public Safety Power Shutoff webpages. (D.21-06-014, Ordering Paragraph 27.)*

Response: SCE frequently updates its Public Safety Partners (PSPs) contact list. SCE has multiple methods for updating contact information for PSPs:

- In advance of peak fire season, SCE sends a list of current contact information to each PSP organization and requests that they review and update their contact list. SCE subsequently updates its PSP contact databases.
 - In advance of peak fire season, SCE conducts two communication tests with PSPs including communication and water/wastewater customers. Bounce backs or bad phone numbers are flagged to the PSPs for updating. These contact verification tests were conducted on February 18-19, 2026 and April 14-15, 2026.
 - PSP contacts are also updated on a real-time basis any time a change in personnel is flagged.
 - SCE will also update contact information during a PSPS event as requested.
3. *PG&E, SCE, and SDG&E must confirm that the utility (1) contacted its Medical Baseline customers, at least annually, to update contact information; (2) sought to obtain from Medical Baseline customers, at least annually, an alternative means of contact for Public Safety Power Shutoff (PSPS) events; (3) contacted all customers that use electricity to maintain necessary life functions, at least annually, to update contact information; and (4) sought to obtain from these customers that use electricity to maintain necessary life functions, at least annually, an alternative means of contact for PSPS events. Provide the IOU's protocol on maintaining the Medical Baseline customer contact list and the electricity reliance customer contact list in a timely manner. The maintenance protocol should include*

the steps, the staffing, and the deadlines to achieve the objectives. (D.21-06-014, Ordering Paragraph 36.)

Response: In May 2026, SCE executed its annual outreach to all Medical Baseline (MBL) customers, including those who rely on electricity to maintain necessary life functions.

SCE generated a report from its billing system identifying all active MBL customers and issued an annual communication requesting customers to (1) review and update their primary contact information and (2) provide an alternative means of contact for PSPS events.

The process includes:

- Annual extraction of MBL customer data from the billing system;
- Development and approval of compliant customer communication;
- Delivery of customer lists and materials to an authorized third-party vendor for translation (Spanish), printing, and mailing; and
- Confirmation of completed distribution and receipt of vendor invoicing.

Customer contact information is maintained within SCE's Customer Information system and updated through customer responses and standard service channels to ensure data accuracy in a timely manner.

Program management, compliance, and vendor oversight teams support implementation, with third-party vendors providing multilingual production and distribution services.

All related documentation, including customer lists, communications, and vendor invoices, is retained in SCE's internal SharePoint repository as evidence of compliance.

Appendix

Appendix A: Community Resource Centers Plan

Appendix B: Critical Facilities and Infrastructure Plan

Appendix C: Notification Plan

Appendix D: PSPS Exercises

Appendix E: Education and Outreach

Appendix F: PSPS Pre-Season Tables

IOUs may include any additional appendices as deemed appropriate. Each appendix must include page numbers.

Appendix A

Community Resource Center Plan

July 1, 2026



Southern California Edison's Community Resource Center Plan for Public Safety Power Shutoff Support Pursuant to Commission Decision in OIR Phase Three of R.18-12-005

Table of Contents

	<u>Page</u>
I. BACKGROUND.....	1
II. OBJECTIVE.....	1
III. CRC STRATEGIES, ACTIONS & TIMING	1
IV. CRC CONTRACTING EFFORT	3
V. TYPE OF CRCS NEEDED	5
VI. CRC SERVICES AND SUPPLIES AVAILABLE	5
VII. CRC INFORMATION TRANSPARENCY AND ACCESSIBILITY	7
VIII. COVID-19 CONSIDERATIONS	7
IX. CRC USAGE METRICS, PROGRAM EVALUATION, LESSONS LEARNED.....	7
X. LESSONS LEARNED.....	8

Section I. Background

On December 19, 2018, the California Public Utilities Commission (Commission or CPUC) opened Public Safety Power Shutoff (PSPS) Order Instituting Rulemaking (R.)18-12-005 (OIR) to examine the rules that allow electric utilities, under the Commission's jurisdiction, to de-energize power lines in case of dangerous conditions that threaten life or property in California. On June 4, 2019, the Commission issued Decision (D.)19-05-042 (PSPS OIR Phase 1 Decision), which established the PSPS Guidelines. The PSPS OIR Phase 2 Decision, D.20-05-051, adopting updated and additional PSPS guidelines was issued on June 5, 2020 and required SCE to provide a Community Resource Center (CRC) Plan. Subsequently, SCE submitted its CRC Plan on August 4, 2020. The PSPS OIR Phase 3 Decision, D.21-06-034, updated the PSPS guidelines and rules to be applied with the Phase 2 and Phase 1 Decision. The PSPS OIR Phase 3 Decision requires SCE to provide an updated CRC Plan annually in the pre-season report. Pursuant to this directive, SCE hereby submits its updated CRC Plan (the Plan).

The Plan includes a description of the steps taken by SCE in identifying potential CRC sites, the criteria for locating CRCs, the considerations for contracting with a CRC site, SCE's process for obtaining feedback from external parties on the Plan, determination of the resources needed to serve the community members who visit the CRC during PSPS events.

Section II. Objective

SCE established CRCs in and adjacent to High Fire Risk Areas (HFRA) to help customers navigate and mitigate the impact of PSPS events. CRCs provide access to device charging, restrooms, water, snacks, ice or ice vouchers, cellular network services, and information about SCE's PSPS resiliency programs and incentives. SCE provides prepackaged fact sheets including California Alternate Rates for Energy (CARE) and Family Electric Rate Assistance (FERA) and Medical Baseline applications, Personal Protective Equipment (PPEs), and small resiliency items in reusable tote bags to help customers manage the event.

Section III. CRC Strategies, Actions & Timing

In Fall 2019, SCE first began providing in-person local support to its customers through Community Crew Vehicles (CCVs). In the days leading up to the declaration of a PSPS event, SCE coordinates with local government to identify suitable locations to deploy a

CCV. CCVs are equipped with backup power that will allow customers to charge their personal mobile devices and may be deployed to communities impacted by PSPS. At CCVs, customers received information/updates from SCE staff about the outage, relevant public safety broadcasts, bottled water, and snacks.

Simultaneously, to streamline the coordination with local government and to enable quicker activation and more robust customer support, SCE contracted with facilities in communities at high risk of PSPS ahead of PSPS. CCVs can be quickly activated to serve customers and can be set up in open areas without a standing facility. The flexibility and extended coverage that these resources provide enhances SCE's ability to support customers during PSPS events.

CRCs are temporary public meeting locations that provide support and services to impacted communities during PSPS de-energization events. In 2019, SCE contracted 13 sites. As of the filing of this CRC Plan, SCE has 116 contracted locations, 113 of which are indoor facilities. SCE currently has eight CCVs that can be deployed to areas affected by an outage event. SCE supplements its portfolio of contracted CRCs with CCVs and pop-up CRCs.

Although CCVs may not offer all the same services and amenities as CRCs, CCVs offer similar informational and resiliency support to community members during PSPS events.

SCE also provides support using pop-up CRCs. Pop-up CRCs are locations that become available through communities and agencies, often as needed with limited pre-planning and without a contract. Pop-up CRCs are useful where there are no contracted CRCs available for SCE to activate in a community. These sites could be indoor or outdoor facilities (e.g., parking lots) not under contract with SCE, offered to SCE for use during PSPS events.

SCE uses customer and CBO feedback to refine its CRC and CCV support offerings and, when appropriate, adds or enhances services to help further mitigate PSPS impacts. In late 2021, SCE made available medical thermal bags to keep small medical items like insulin cold for de-energized customers and language translation service for over 120 languages including American Sign Language. In 2022, SCE made available wheelchairs and privacy screens and piloted a service that gives customers the option to leave their medical devices at a CRC for charging. In 2023, SCE made available an

in-event battery loan pilot program and the Disability Disaster Access & Resources (DDAR) pilot program for customers. In 2024, SCE offered water bowls and treats for service animals and sensory kits. In 2025, SCE provided AFN table signs to promote and share what type of services SCE offers to customers with disabilities. In 2026, SCE continues to explore additional CRC services to support customers with AFN.

In 2022, SCE began participating in Community Safety Fairs (CSFs) to better prepare customers ahead of potential PSPS events. This includes helping customers update their contact information, enroll in outage alert notifications, and be made aware of all the relevant programs and local community resources that can help them during a PSPS event. CSFs also provide SCE with opportunities to meet in person with members of the local emergency response team such as the Sheriff's Department, Fire Department, local Community Emergency Response Teams, and the American Red Cross. In 2022, SCE connected with over 1,000 customers in 9 communities. Because of the positive feedback from the communities, SCE continued to participate in CSFs in 2023. In 2023, SCE participated in six CSFs, four of which were tribal communities, resulting in over 1,000 customer connections. In 2024, SCE participated in seven CSFs resulting in over 800 customer connections. In 2025, SCE participated in five CSFs that resulted in approximately 280 customer connections. In 2026, SCE has already participated in four CSFs that resulted in approximately 456 customer connections.

In August 2025, SCE onboarded a third-party vendor to support CRC staffing during PSPS. This addition strengthens SCE's ability to maintain adequate staffing coverage across CRC locations during large-scale PSPS events. The vendor also supports CRC setup, operations, demobilization, and customer inquiries. The vendor has been integrated into SCE's existing PSPS processes and is positioned to support SCE during the 2026 PSPS season.

Section IV. CRC Contracting Effort

To ensure the timely availability and seamless activation of CRCs, SCE formalizes CRC arrangements through contractual agreements. These agreements define key operational elements, including activation protocols, response times, and site-specific contact information.

In identifying communities with greater need for CRC support, SCE engages local governments and community-based organizations (CBOs) to obtain recommendations for suitable CRC locations and services. While SCE has received input from local and

tribal governments, emergency management offices, and public health officials regarding potential CRC siting, feedback on additional CRC services has been limited. (See Section VII, *CRC Services and Supplies Available*.) Additionally, SCE has not received input on alternative locations where customers may access electricity during periods when CRCs are closed. To address this gap, SCE provides publicly available resources on its website, including: (1) an outage map displaying the energization status of specific addresses; (2) a list of participating hotels offering discounted overnight accommodations to impacted customers; and (3) contact information for 211, a nonprofit organization that connects individuals with essential community services.

SCE evaluates multiple factors when identifying appropriate CRC locations. A primary consideration is whether a community previously affected by PSPS lacked access to a CRC. SCE further refines potential locations based on input from stakeholders with knowledge of local conditions and community needs. These stakeholders include local and tribal governments, Public Safety Partners, hotels, representatives of individuals with access and functional needs, senior groups, business owners, public health and healthcare providers, and community-based organizations.

In selecting CRC sites, SCE prioritizes facilities that serve as established community gathering places and are accessible via public transportation. To qualify as a CRC, a facility must meet minimum requirements, including:

- Operating hours from 8:00 a.m. to 10:00 p.m., unless the site is a government facility subject to earlier mandated closure
- Capacity to accommodate at least 15 individuals in an open and comfortable space
- Compliance with the Americans with Disabilities Act (ADA), or equivalent accessibility
- Climate control
- Access to restrooms
- Sufficient electrical outlets to support charging multiple electronic devices
- On-site parking
- At least two egress routes
- Cellular network reception

Additional considerations in CRC selection include proximity to HFRA, community demographics, and the availability of other CRC sites in the vicinity. SCE also prioritizes locations in publicly recognizable areas. The current CRC portfolio reflects these criteria and is built through community partnerships, encompassing facilities operated by small

businesses, retail establishments, recreational centers, nonprofit organizations, hotels, and public agencies.

SCE continues to collaborate with community partners to expand CRC availability and enhance support for customers impacted by PSPS events. Currently, SCE has executed agreements for 116 CRC sites, 108 of which can operate during de-energization events in accordance with the required hours of 8:00 a.m. to 10:00 p.m. Some CRC agreements were established prior to the issuance of D. 20-05-051 and therefore include operating hours that differ from current requirements. SCE has requested that these sites extend their hours where feasible. Sites that are unable to meet the required hours have been retained as backup locations and are activated on an as-needed basis, for example, when no alternative site in an affected community is available to meet the required operating hours. For all new CRC contracts, SCE requires operating hours consistent with D.20-05-051, except for government-owned facilities, which may close in accordance with mandated operating schedules.

Section V. Type of CRCs Needed

SCE uses contracted CRCs, CCVs, and pop-up CRCs to support communities impacted by PSPS. Please see Section III (CRC Strategies, Actions & Timing) for details.

Section VI. CRC Services and Supplies Available

During an active PSPS, SCE coordinates with Public Safety Partners to notify and activate contracted CRCs in affected communities. Upon confirmation of site availability, SCE shares CRC details with Public Safety Partners for further dissemination through local communication channels. SCE also provides CRC information publicly via SCE.com and social media platforms, including facility name, address, services, operating hours, and whether the site is indoor or outdoor.

CRCs provide a standard set of services, including device charging, bottled water, light snacks, ice or ice vouchers, seating, restrooms, access to communication services, and live representatives to support customer inquiries. CRCs also offer resiliency kits; information on PSPS programs and incentives; assistance with outage alerts and customer contact updates; and PSPS event information. SCE recently enhanced resiliency kits to include a flashlight, lantern, fire-retardant blanket, and hygiene kit.

CRCs are designed to support customers with AFN. Customers may charge compatible medical devices, and all CRC sites are confirmed to be accessible prior to activation. For outdoor sites, SCE provides accessible portable restrooms. CRCs also offer emergency preparedness resources specific to AFN populations. SCE has established partnerships with five Independent Living Centers (ILCs), which can activate as CRCs and support preparedness and resiliency efforts for customers with disabilities.

SCE continues to evaluate and enhance AFN-related services. Enhancements have included medical thermal bags and expanded language translation services (more than 120 languages, including American Sign Language) and the addition of privacy screens, wheelchairs, and a device charging “leave-behind” option. SCE continues to engage stakeholder groups, including its AFN Core Planning Team, to identify further improvements.

While standard CRC services meet most community needs, SCE considers local demographics and conditions when activating CRCs and may provide supplemental services as appropriate. For example, SCE may provide bulk water in communities that rely on electrically powered well systems.

Although SCE does not control cellular network operations, CRCs are sited in locations with expected cellular reception under normal conditions. Consistent with D. 20-07-011, SCE coordinates with telecommunications providers and provides advance notice of potential PSPS events, typically one to three days in advance.

To support communications during PSPS events, CRCs are equipped with two MiFi devices (Verizon and AT&T). Where necessary, SCE may deploy extended-range devices or coordinate with telecommunications providers on additional solutions, such as backup generators or mobile cell sites. SCE added Starlink satellite devices as an additional communication solution and integrated select units into CCVs to enhance deployment efficiency.

SCE will continue to adapt CRC services in response to evolving customer needs, operating conditions, and stakeholder input.

Section VII. CRC Information Transparency and Accessibility

SCE has made comprehensive CRC information, including potential or actual locations publicly available and accessible with searchable functions on a de-energization webpage in advance of fire season. SCE's PSPS webpage¹ and Outage Map² provide a comprehensive list of all SCE's contracted CRC locations.³

When a PSPS de-energization event has been activated, SCE posts on SCE's PSPS webpage the hours, locations, and whether it's an indoor or outdoor site for each CRC as each facility's availability is confirmed, SCE makes every attempt to post CRC hours and locations within 24 hours prior to opening the site. Description of CRC services are posted ahead of PSPS de-energization events and are generally standard across all CRCs.

PSPS notices direct customers to SCE's website for the latest information and availability of community resources. SCE also shares this information with local emergency response teams and CBOs to share through their respective communication channels with the communities.

The PSPS preparedness information shared at the in-person CRCs and CCVs will also be available virtually on our website at www.sce.com. Customers can visit [Check Outage Status](#) for activated CRC and CCV sites during PSPS events.

Section VIII. COVID-19 Considerations

As described in section III (CRC Strategies, Actions, & Timing) above, during the COVID-19 pandemic, SCE modified community support to customers impacted by PSPS de-energizations. With the end of the pandemic, SCE will no longer continue its social distancing protocols unless required by local communities but will continue to make available hand sanitizers to help control spread of any contagion.

Section IX. CRC Usage Metrics, Program Evaluation, Lessons Learned

Please see Tables 3, 4, and 5 of the 2026 PSPS Pre-Season Tables for SCE's CRC usage metrics, customer feedback, and challenges when setting up CRCs.

¹ See <https://www.sce.com/wildfire/pssp>

² See <https://www.sce.com/outage-center/check-outage-status>

³ See [Community Resource Centers During Emergencies | SCE](#)

Section X. Lessons Learned

SCE has included lessons learned in Table 14 of its 2026 PSPS Pre-Season Tables.

Appendix B

Critical Facilities and Infrastructure Plan

July 1, 2026



Southern California Edison's Critical Facilities and Infrastructure Plan for Public Safety Power Shutoff Support Pursuant to Commission Decision in OIR Phase Three of R.18-12-005

Table of Contents

	<u>Page</u>
I. Background	1
II. Objectives	1
III. Strategies, Action and Timing	1
IV. CFI Definition and Contact on PSPS Website	1
V. Identification Method of CFI.....	3
VI. Changes in CFI Since Prior Report	3
VII. Maintenance and Update Process of CFI List.....	3
VIII. Collaboration with Transmission-Level Customers.....	4
IX. Comparison of Current Year CFI Request Total With Last Year	4
X. CFI Backup Power Assessment Efforts/Actions, Backup Power Provisions and Terms	4
XI. Engagement with Local Government and Public Safety Partners on CFI Identification and Backup Generation Need	5
XII. Maintenance and Accessibility on Public Safety Partner Portal.....	5
XIII. Consultation With Local and Tribal Governments.....	5
XIV. Coordination to Maintain Energization (including Backup Power Assessment)	6
XV. Lessons Learned.....	6

I. Background

On December 19, 2018, the California Public Utilities Commission (Commission or CPUC) opened Public Safety Power Shutoff (PSPS) Order Instituting Rulemaking (R.)18-12-005 (OIR) to examine the rules that allow electric utilities, under the Commission’s jurisdiction, to de-energize power lines in case of dangerous conditions that threaten life or property in California. On June 4, 2019, the Commission issued Decision (D.)19-05-042 (PSPS OIR Phase 1 Decision), which established the PSPS Guidelines. The PSPS OIR Phase 2 Decision, D.20-05-051, adopting updated and additional PSPS guidelines was issued on June 5, 2020. On June 29, 2021, the Commission issued D.21-06-034 (PSPS OIR Phase 3 Decision) adopting updated and additional PSPS guidelines and requiring IOUs to provide annually in a pre-season report a Critical Facilities and Infrastructure (CFI) Plan. On June 3, 2021, the Commission issued D.19-11-013 (PSPS OII Decision) adopting certain corrective actions based on the 2019 fire season. Pursuant to these directives, SCE hereby submits its CFI Plan (the Plan).

II. Objectives

The objective of SCE’s CFI plan is to provide State Agencies, public safety partners, critical infrastructure and facilities providers, customers, and all interested stakeholders with accessible, actionable and easy to understand information on how SCE defines, identifies, and coordinates with CFI customers to support resiliency before, during and after PSPS that may impact them.

III. Strategies, Action and Timing

SCE aims to work collaboratively with CFI customers to help them prepare for wildfire season. SCE conducts various actions throughout the year including annual communication prior to wildfire season to verify contact information, remind customers to be prepared, and provide backup generation information. SCE also hosts annual CFI workshops that provide a PSPS program overview and education, information on customer programs and available resources. SCE’s annual workshops include customer-shared best practices on resiliency during a PSPS.

IV. CFI Definition and Contact on PSPS Website

Facilities and infrastructure deemed to be critical are those that perform essential functions for public safety. Some examples include, but are not limited to, police facilities, emergency operation centers (EOCs), fire stations, schools, shelters, and telecommunications towers. These facilities may require additional assistance and advanced planning to ensure resiliency and continuity during de-energization events. SCE offers assistance to those facilities with advanced planning consultations that support their functional resiliency during de-energization and re-energization.

The Commission adopted the following list of CFI, aligned with the Department of Homeland Security’s Critical Infrastructure Sectors.¹

¹ See D.19-05-042, D.20-05-051 and D.21-06-34 in R. 18-05-012.

Critical Facilities and Critical Infrastructure Sectors:

- Emergency Services Sector
 - Police Stations
 - Fire Station
 - Emergency Operations Centers
 - Tribal government providers
- Government Facilities Sector
 - Schools
 - Jails and prisons
 - Homeless Shelters
 - Community Centers
 - Senior Centers
 - Independent Living Centers
 - Voting centers and vote tabulation facilities
- Healthcare and Public Health Sector
 - Public Health Departments
 - Medical facilities, including hospitals, skilled nursing facilities, nursing homes, blood banks, health care facilities, dialysis centers and hospice facilities
 - Cooling (or warming) Centers
 - Temporary facilities established for public health emergencies
- Energy Sector
 - Public and private utility facilities vital to maintaining or restoring normal service, including, but not limited to, interconnected publicly-owned utilities and electric cooperatives
- Water and Wastewater Systems Sector
 - Facilities associated with the provision of drinking water or processing of wastewater including facilities used to pump, divert, transport, store, treat and deliver water or wastewater
- Communications Sector
 - Communication carrier infrastructure including selective routers, central offices, head ends, cellular switches, remote terminals and cellular sites
- Chemical Sector
 - Facilities associated with the provision of manufacturing, maintaining, or distributing hazardous materials and chemicals.
- Food and Agriculture Sector
 - Emergency Feeding Organization, as defined in 7 U.S.C. § 7501.(Food Banks)
- Transportation Systems Sector
 - Traffic Management Systems

SCE's PSPS site on SCE.com² includes a CFI page that designates a contact for customers, in addition to their Account Managers, to address related questions.

Website Contact on PSPS Website:

CONTACT US

To add your business to our designated roster of critical facilities and critical infrastructure, or if you have other questions, please contact your account manager, or send an inquiry to:

Maria Rios

Senior Advisor, Customer Service

SCECSCustomerSupport@sce.com ✉

V. Identification Method of CFI

SCE identifies CFI customers by using the Commission's adopted CFI list and the North American Industry Classification System (NAICS) process, which allows to verify the sectors identified by the CPUC. SCE reviews customer data against NAICS classifications and flags qualifying accounts accordingly.

In addition to developing and maintaining its own CFI list, SCE coordinates with first/emergency responders, local and tribal governments, public safety partners, and operators of critical facilities and infrastructure to identify facilities within SCE's service territory, confirm appropriate points of contact, and support preferred communication methods for PSPS-related coordination.

VI. Changes in CFI Since Prior Report

As of May 30, 2026, SCE has 10,261 unique CFI accounts, which is 1,932 more than the number reported in its 2025 Pre-Season Report. The increase is due to SCE's ongoing efforts in 2025 and 2026 to standardize NAICS codes to the latest standard and identify NAICS codes for previously unclassified accounts.

VII. Maintenance and Update Process of CFI List

SCE uses multiple processes throughout the year to maintain and verify CFI customer contact information. Annually, SCE distributes a communication requesting that CFI customers review and update their contact information through the SCE.com Preference Center or by working directly with their assigned SCE Account Manager. In addition, Account Managers proactively

² SCE Critical Facilities and Critical Infrastructure webpage is available <https://www.sce.com/wildfire/critical-facilities-infrastructure>.

validate customer contact information through ongoing customer engagement, including both in-person and virtual meetings.

To further support contact information accuracy, SCE conducts annual Critical Infrastructure workshops that provide customers with opportunities to review and update their contact details. SCE also performs two communication notification tests each year prior to wildfire season. In 2026, these tests were conducted on February 18, 2026, and April 14, 2026 for all customers, including CFI customers located in High Fire Risk Areas (HFRA) and on downstream circuits. Notifications were sent via email and text message using the contact information on file. Following each test, SCE reviews communication delivery status reports to identify unsuccessful notification attempts and conducts follow-up outreach, as necessary, to obtain updated customer contact information and improve data accuracy.

Key communication service providers are assigned to an Account Manager that serves as their primary point of contact. SCE continues to partner with telecommunication customers through broader outreach and direct leader to leader engagement.

SCE provides its CFI list in Table 6 of SCE's 2026 Pre-Season Report, Appendix F.

VIII. Collaboration with Transmission-Level Customers

SCE collaborates with transmission-level customers to better understand their unique operational needs and support their preparedness for the upcoming wildfire season, which enables them to effectively support their own customers, which may include CFI. SCE sends an annual communication to transmission-level customers to promote PSPS preparedness and to remind transmission-level customers to confirm their systems' readiness during PSPS. Additionally, SCE conducts an annual workshop to update transmission-level customers on PSPS protocols and how to prepare for the upcoming wildfire season.

IX. Comparison of Current Year CFI Request Total With Last Year

SCE has not received any requests from customers to be designated as critical facilities and infrastructure in the past two years.

X. CFI Backup Power Assessment Efforts/Actions, Backup Power Provisions and Terms

All critical facilities and critical infrastructure facilities should have resiliency plans including backup generation as a best practice, given that unexpected electrical emergencies could be caused by many factors outside of the control of SCE, including earthquakes or other sources of disruption. Some categories of providers, including telecoms and hospitals, are required by law or regulation to do so. SCE works with all categories of providers to inform them about the need for backup generation and to offer support in resiliency planning. SCE offers these customers the option to contact SCE to request a backup generation assessment. If requested, SCE will work with the CFCI customer to discuss backup power solutions to increase resiliency in the event of an emergency. Although SCE is not required to provide backup generation to critical facilities and critical infrastructure, SCE has developed a pilot program to support K-12 public school

sites that were disproportionately impacted by PSPS. As of May 31, 2026, SCE has deployed 11 temporary generators to targeted K-12 school sites. While the goal of the pilot is to support targeted schools during the upcoming PSPS season, SCE will work with each school site to determine if a more durable/permanent resiliency solution is feasible. In 2026, SCE contacted all its CFI customers to encourage them to update their business resiliency plans and consider adding backup generation. Please see Table 6 of SCE's 2026 Pre-Season Report, Appendix F to see the names of all the CFI customers that SCE contacted to determine whether they have backup generation, the date of the communication, whether a backup power assessment was requested, the result of the assessment, and whether or not the CFI provided any needed generation.

During PSPS, SCE coordinates with public safety partners to address public health or safety concerns, including a back-up generation for critical facilities. In these instances, SCE will provide a list of generator vendors that CFI customers can contract with directly. If necessary, SCE will engage county offices of emergency management and will partner on solutions including deployment of backup generation if necessary.

XI. Engagement with Local Government and Public Safety Partners on CFI Identification and Backup Generation Need

SCE works with local and tribal governments, Federal and State government agencies, and other private and public sector parties to identify transportation, communications, and water system infrastructure facilities within SCE's service territory, to confirm back-up generation.

XII. Maintenance and Accessibility on Public Safety Partner Portal

SCE's Public Safety Partner Portal (PSPP) provides public safety partners with a list of the CFI customers and related facilities in their jurisdiction. Critical Infrastructure information is updated regularly.

XIII. Consultation With Local and Tribal Governments

SCE routinely meets with local and tribal governments to describe SCE's PSPS policies and customer resources, identify critical infrastructure, contact updates to ensure timely and accurate notifications, educate public safety partners on how to access and use the PSPS Public Safety Partner Portal, identify suitable Community Resource Center (CRC) and Community Crew Vehicle (CCV) locations, and respond to questions and concerns raised by elected officials and staff. SCE Account Managers also provide targeted outreach to critical facilities and infrastructure including schools, spot-municipal utilities, water and waste-water management, and tribal accounts.

In addition to routine outreach and consultation with tribal partners, SCE also offers tribal-specific opportunities such as the Tribal Leaders Energy Summit. SCE also works with the SoCal Tribal Emergency Managers group to engage and educate on critical infrastructure, tribal resiliency and PSPS. Workshops also provide an overview to critical infrastructure customers on programs, such as the Self-Generation Incentive Program (SGIP) program, Medical Baseline

(MBL) Critical Care Battery (CCB), Microgrid Incentive Program, “Tribal Mini Grant” program to enroll eligible tribal customers in various cost-saving and customer resiliency programs, and grant opportunities available to tribes through other agencies and resources such as the Environmental Protection Agency (EPA), Department of Energy (DOE) and California Energy Commission (CEC).

XIV. Coordination to Maintain Energization (including Backup Power Assessment)

SCE provides its public safety partners with an annual resource guide that gives them information, links and contacts for accessing the Public Safety Partner Portal, information on services provided at CRCs and via its CCVs as well as programs available for customers with Access and Functional Needs (AFN). We also encourage our customers to be resilient and prepared for power outages. Many of these customers are required by law or industry standards to have backup generation in place to sustain critical operations in the event of a power outage, regardless of outage type. Other customers that are not required to have backup generation are still encouraged to consider adding this capability if they feel they have critical needs that must continue in a power outage.

In 2026, SCE conducted workshops for all CFI customers in the following sectors: water agencies, communications, food banks, healthcare, schools, chemical, sub-transmission level customers, tribal nations, transportation, and primary-metered customers. These workshops stressed the importance of having a resiliency plan and potentially including backup generation in preparation for wildfire season.

Notwithstanding these efforts and requirements, if CFI customers do not have the ability to sustain critical life and safety operations during an extended power outage, SCE typically coordinates these requests with its county emergency management agency partners to identify and prioritize backup generation needs requested by the county.

XV. Lessons Learned

SCE had no lessons learned related to CFI to report for this reporting period; however, SCE continues to incorporate broader PSPS program improvements to enhance CFI support and coordination.

Appendix C

Notification Plan

July 1, 2026



Southern California Edison's Notification Plan for Public Safety Power Shutoff Plan Pursuant to Commission Decision (D.) 21-06-034

Table of Contents

Background	6
Objectives	6
Strategies, Actions, and Timing	6
Timing and Notification Types	7
Notification Process Planning and Improvement	11
Systems.....	11
Complaints	12
Updated/Current Notification Script and Templates	12
In-language Translations	12
Notification Methods	13
Customers	13
Public Safety Partners and Local Jurisdiction Notifications.....	13
Address Level Alerts: Non-Customers including Stakeholders and Transient Populations	14
Joint IOU Coordination on PSPS Notifications for Shared Customer	14
Meeting Notification Timeline Requirements.....	15
Watch Phase:	15
Alert Phase:	15
Warning and De-energization Phases	16
Restoration Phase	17
Notification Accuracy and Precision	18
Accuracy and Precision.....	18
Increased Stability of Forecasting.....	18
Entity Responsible for Notifications.....	19
Consistency of PSPS Notification Information Across All Platforms	19

Customer Access to PSPS Event Information on SCE.com	19
News and Social Media.....	19
Direct Mail	20
Advertising	20
Phone.....	20
Online	21
Additional Collateral	21
Coordination with Stakeholders.....	21
Community Meetings	21
Affirmative Notifications to Medical Baseline Populations and Any Self-Identified Vulnerable Populations.....	22
Stakeholder Meetings.....	22
Notification Strategies for Reaching AFN Customers	22
Public Warning of PSPS Events Such as Week-Ahead Forecasts.....	24
Notification Cancellation	24
Transmission-Level Customer Notification.....	24
Impacted Customer Information Available to Public Safety Partners, Critical Facilities and Critical Infrastructure from Outset of PSPS	24
Secure Portal for Public Safety Partners	25
Lessons Learned.....	25
Attachment A Notification Templates/Scripts	26
PSPS Variable Notification Templates - Local/Tribal Governments and Community Based Organizations (CBOs) Working Within the Access and Functional Needs (AFN) Community.....	27
Template Language for All Notifications (After Notification Language)	27
Advanced Initial (72-hour) LNO Notification (Advanced Initial)	28

Updated Conditions (Update) Notification	29
Expected De-Energize Notification (previously: Imminent De-Energization) (PSPS Expected).....	30
PSPS Shutoff Notification (De-energization notification).....	30
Preparation for Restoration	31
Restore Notification (formerly: RE-ENERGIZE) Restoration Notification	32
Cancellation No Longer in Scope	33
Event Concluded Notification.....	33
PSPS Variable Notification Templates - Customer.....	34
Advanced Initial.....	34
Initial Notification Alert	35
Update Notification Warning	36
Cancellation.....	37
PSPS Expected	39
PSPS Shutoff.....	40
Continued Shutoff - Next Day Shutoff Update.....	41
Prepare for Restoration	42
Restored No Longer in Scope.....	44
Restored in Scope – Risk of PSPS Remains	45
Address Level Alerts Notification Templates.....	47
Initial Notification Alert	47
Update Notification Warning.....	48
Cancellation	49
PSPS Expected Warning	50
PSPS Shutoff	52
Sent At Authorization To De-Energize	52

Continued Shutoff - Next Day Shutoff Update.....	53
Prepare For Restoration.....	54
Restored No Longer in Scope.....	55
Restored in Scope– Risk of PSPS Remains.....	56
PSPS Notification Cadence	58

Background

On December 19, 2018, the California Public Utilities Commission (Commission or CPUC) opened Public Safety Power Shutoff (PSPS) Order Instituting Rulemaking (R.)18-12-005 (OIR) to examine the rules that allow electric utilities, under the Commission's jurisdiction, to de-energize power lines if dangerous conditions threaten life or property in California. On June 4, 2019, the Commission issued Decision (D.)19-05-042 (PSPS OIR Phase 1 Decision), which established the PSPS Guidelines. The PSPS OIR Phase 2 Decision, D.20-05-051, adopting updated and additional PSPS guidelines was issued on June 5, 2020 and required SCE to develop notification plans jointly with CALOES, county and local governments, independent living centers, and representatives of people/communities with access and functional needs.¹ The PSPS OIR Phase 3 Decision, D.21-06-034, updated the PSPS guidelines and rules to be applied with the Phase 2 and Phase 1 Decision. The PSPS OIR Phase 3 Decision required SCE to provide annually in a PSPS pre-season report its Notification Plan. Pursuant to this directive, SCE submits its updated Notification Plan (the Plan).

Objectives

The objective of SCE's notification strategy is to provide customers and Public Safety Partners; critical infrastructure and facilities providers; including those with access and functional needs; and impacted communities with accessible, actionable, and easy to understand information before, during and after Public Safety Power Shutoff (PSPS) events that may impact them. Customers and community members should be informed at all stages of a PSPS so they can be safe and secure during PSPS outages.

Strategies, Actions, and Timing

A comprehensive alert and warning program is essential to a community's ability to effectively respond to emergencies, including Public Safety Power Shutoffs. SCE has established a comprehensive, coordinated, and cohesive messaging protocol that provides priority notifications to

¹ D.21-05-051, p. 3.

Public Safety Partners, critical facilities and infrastructure customers, and transmission-level customers, and it complies with all standard emergency alerting and warning protocols.

SCE continues to partner with multiple agencies and organizations to educate, provide outreach, obtain feedback, and develop solutions to customer concerns related to PSPS. SCE understands that insufficient advance notice could result in customers and the public not being adequately prepared. As such, SCE continues to enhance processes and technology to improve the informativeness, accuracy and timeliness of notifications.

Timing and Notification Types

In accordance with the State of California Alert and Warning Guidelines, SCE divides PSPS event planning into phases (plus normal/no activity phase). These are reflected in customer and public safety notifications, on [SCE.com/PSPS](https://www.sce.com/PSPS) and on [SCE.com/weather-awareness](https://www.sce.com/weather-awareness):

- PSPS Normal: No activity
- PSPS Watch: 4-7 days
- PSPS Alert: 2-3 days
- PSPS Warning: ≤ 1 day
- In-event notifications
- Event concluded/cancellation notifications

Table 1**Notification Descriptions**

Type of Notification	Recipients	Description
Advance Initial or Initial (Alert)	Public Safety Partners and Critical Facilities & Infrastructure, including local and Tribal governments, Community Choice Aggregators (CCA), hospitals, water/wastewater and telecommunications providers, Community Based Organizations (CBOs) and paratransit agencies serving the Access and Functional Needs (AFN) community.	Initial notification of potential PSPS event when circuits are first identified for potential de-energization (≥48 hours before potential de-energization)
Initial or Update (Alert)	Customers including multi-family building account holders and address level alert (ALA) enrolled non-account holders.	Initial notification of potential PSPS event (≥24 hours before potential de-energization).
Update (Alert)	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	PSPS event status update notification to alert for any changes or additions/deletions to current scope, including all clear for circuit(s) removed from scope (timing varies and may also occur daily).
Expected (Warning)	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications	Power shutoff expected soon (1-4 hours before potential de-energization).

Type of Notification	Recipients	Description
	providers, CBOs and paratransit agencies serving the AFN community.	
PSPS Expected (Warning)	Customers including multi-family building account holders and ALA enrolled non-account holders.	Power shutoff expected soon (1-4 hours before potential de-energization).
Shutoff	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	Power has been shut off (when de-energization is initiated).
	Customers including multi-family building account holders and ALA enrolled non-account holders.	
Continued Shutoff	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	Status update to customers with overnight de-energization.
Prepare to Restore	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	Inspection/patrols of de-energized circuits for PSPS restoration has begun and power will be restored shortly. (re-energization is imminent)

Type of Notification	Recipients	Description
	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	
Restoration Time Pending	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	Customer is de-energized and estimated restoration time is pending inspection results.
Restoration Time Update	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	Restoration exceeds 8 hours or updated timing for customers who received Restoration Time Pending notification
Restore	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	Power has been restored.
Restored No Longer in Scope	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	Power has been restored and the PSPS event concluded-no further PSPS expected.
Restored In Scope	Customers including multi-family building account holders and address level alert ALA enrolled non-account holders.	Power has been restored but the PSPS event remains ongoing, re-energization is temporary and additional PSPS risk is possible.

Type of Notification	Recipients	Description
Public Safety Partner Event Concluded	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	PSPS event is concluded, and no further de-energization expected.
Public Safety Partner Event Concluded	Public Safety Partners and Critical Facilities & Infrastructure including local and Tribal governments, CCA, hospitals, water/wastewater and telecommunications providers, CBOs and paratransit agencies serving the AFN community.	PSPS event is concluded, and no further de-energization expected.

Notification Process Planning and Improvement

SCE is committed to improving the clarity, cadence, and accuracy of customer notifications to better meet customers' needs, and to evaluate and improve the effectiveness of our notification delivery systems. SCE continues to prioritize promoting customer awareness and education and implementing lessons learned from current and past PSPS events. In preparation for the 2025 season, enhancements were implemented to improve PSPS notifications.

Systems

Workflow optimization work has continued to improve accuracy and timeliness. System latencies were reduced to improve the timeliness of notification to customers. Additionally, user interfaces and in-event reports were upgraded for better situational awareness.

Complaints

SCE captures and tracks PSPS-related customer complaints received through a complaint tracking system. Complaint numbers and nature are documented in post-event reports. SCE also provides additional details on complaints in its annual post-season report filed on March 1.

Updated/Current Notification Script and Templates

Please see [Attachment A](#) for SCE's current notification scripts and templates.

In-language Translations

SCE currently distributes PSPS customer notifications in twenty-three languages:

English	Korean	Arabic	Hmong	Mixteco
Spanish	Tagalog	Japanese	Portuguese	Zapoteco
Mandarin	Khmer	Russian	Hindi	Purépecha
Cantonese	Armenian	Punjabi	French	
Vietnamese	Farsi	Thai	German	

Customers can sign up for language preferences at the SCE preference center and then receive all notifications in their chosen language.

Additional static translations into all prevalent languages are available through various channels. For voice calls, numerical options allow customers to receive their message in their preferred language. For emails, links to read the message in another language are embedded in email correspondence. Once selected, the links lead customers to customized landing pages on SCE.com. SMS text messages include links for Spanish and Asian languages directing customers to customized landing pages on SCE.com.

As of August 2024, notifications are available via an American Sign Language (ASL) link. ASL notifications include English voice over and a screen, and Braille refresh reader accessible transcript of the notification.

PSPS website information, including PSPS outage landing pages, FAQ and outreach materials are available in all 19 prevalent languages (including English). Additionally, the wildfire and PSPS pages on SCE.com are translated into all prevalent languages mandated by the CPUC in D.20-03-004.²

Notification Methods

Customers

In advance of potential PSPS activations that may impact them, the PSPS notification program informs state agencies, public safety partners, critical facilities and infrastructure, and all customers (including access and functional needs populations).

SCE delivers PSPS notices via the recipient's preferred communication channel (voice, email, or SMS) according to the schedule outlined in Table 1: Notification Descriptions.

Public Safety Partners and Local Jurisdiction Notifications

SCE keeps public safety partners, including local and tribal governments, first responders, and critical infrastructure operators informed before, during, and after potential PSPS events.

Notifications are sent through email, text, and phone calls.

These alerts follow the California Alert and Warning Guidelines and include key details like who's issuing the alert, what the threat is, where it's happening, what actions to take, and links to helpful resources on SCE's PSPS webpage, [sce.com/PSPS](https://www.sce.com/PSPS). Public safety agencies can also use these messages as templates for their own Emergency Notification Systems (ENS).

SCE starts with early alerts via text or phone to key contacts, followed by official updates with time-sensitive details. Stakeholders contact lists are updated ahead of fire season and adjusted in real time as needed during PSPS activations.

To support coordination, SCE provides a dedicated liaison email and a toll-free number for local governments to use during PSPS events. We also share tailored PSPS information that local and

² Decision on Community Awareness and Public Outreach Before, During and After a Wildfire, and Explaining Next Steps for Other Phase 2 Issues (March 12, 2020.)

tribal governments, as well as community-based organizations, can use in their outreach to residents and businesses.

Address Level Alerts: Non-Customers including Stakeholders and Transient Populations

Address-Level Alerts (ALA) allow Southern California Edison (SCE) to notify individuals about Public Safety Power Shutoff (PSPS) events, even if they are not SCE customers. Anyone can sign up to receive alerts for a specific address—regardless of residency or account status. This includes caregivers, tenants, landlords, family members, travelers, sub-metered tenants, and individuals without a fixed address. Registrants can choose their preferred communication method and language; alerts are available via SMS, voice or email in seven prevalent languages.

ALA ensures that people who rely on or support those in affected areas can stay informed and take appropriate action. In addition to these direct alerts, SCE also shares PSPS information through public channels such as [sce.com](https://www.sce.com) and social media, making it accessible to everyone.

Joint IOU Coordination on PSPS Notifications for Shared Customer

SCE, in partnership with San Diego Gas & Electric (SDG&E) and Pacific Gas & Electric, coordinates closely to ensure consistent and effective PSPS notifications for shared customer; those who one Investor-Owned Utility (IOU) supplies electrical service but another IOU meters and bills the customer. This collaboration is managed through the Joint IOU Working Group and its External Engagement & Customer Experience Sub-Committee, which meets regularly to align notification practices, data sharing, and customer outreach strategies.

Each utility maintains its own notification systems and criteria for PSPS events, but they work together to benchmark processes and share best practices. The IOUs also coordinate public-facing resources. Customers are directed to utility-specific PSPS update pages:

SCE: [sce.com/psps](https://www.sce.com/psps)

PG&E: [pge.com/pspsupdates](https://www.pge.com/pspsupdates)

SDG&E: [sdge.com/psps](https://www.sdge.com/psps)

These efforts are supported by ongoing benchmarking, shared outage management strategies, and joint planning sessions to improve customer experience and ensure timely, accurate, and accessible notifications across service territories

Meeting Notification Timeline Requirements

SCE makes every effort to send notifications at each phase of the event (Table 1.)

Watch Phase:

Seven Days Out

At seven-days out, or when initially forecast (if less than 7 days), SCE provides county-level watch information on [sce.com/weather-awareness](https://www.sce.com/weather-awareness).

Alert Phase:

Three Days Out

SCE activates the Incident Management Team (IMT) up to 72 hours prior to when circuits are forecast to meet or exceed PSPS criteria.

This triggers direct communications with County Offices of Emergency Services as well as the initiation of the notification program.

The POC identifies the expected timing for the event at the circuit level, and the monitored circuit list (MCL) lists the circuits in scope. The POC and MCL are based on weather forecasting. Emergent weather might shorten the time span for notification. Additionally, changing weather conditions mean that some of those notified this far in advance from the start of POC might ultimately not be impacted by the most severe weather, and might not be subject to PSPS.

As forecasting becomes more precise over the next three days, the notification program at this point is limited to priority notification entities, public safety partners, critical infrastructure and facilities providers, and transmission level customers. Event information is also posted to both the public safety partner portal and to [sce.com/outages](https://www.sce.com/outages).

Public Safety notifications are sent on a jurisdictional basis, consolidating all circuits within the jurisdiction that are in scope on a spreadsheet. Similar information is posted to the public safety partner portal.

Critical infrastructure customers receive location-specific notifications for each customer's location on the monitored circuit list.

Two Days Out

Between 24 and 48 hours out from any event, SCE makes every effort to notify all customers in scope (including access and functional needs of populations) about the upcoming potential event. This notification window is dependent on the weather forecast, and emergent weather might shorten the time span. Additionally, changing weather conditions mean that some of those notified this far in advance from the POC might not be impacted by the most severe weather, and might not be subject to PSPS.

Warning and De-energization Phases

Public Safety Partner Updates

All jurisdictional partners with circuits still on the Monitored Circuit List will receive updates on which circuits within their area remain in scope for the event. Public Safety Partners are encouraged to access detailed information through SCE's Public Safety Partner Portal.

To support situational awareness, SCE also provides a courtesy consolidated spreadsheet with the same information in Excel format. This allows partners to easily review and share circuit details as needed.

Expected Notification

Whenever possible, all customers at risk of being de-energized are provided with a "PSPS Expected" notification within 1-4 hours of the initiation of de-energization. Some customers notified at this

stage will not be de-energized due to successful switching efforts³ or changing weather conditions. Emergent or fast-moving weather might mean that some customers will not receive this notification within the 1–4-hour timeframe.

If customers who receive this notification are not de-energized within this 3-hour window but continue to be at risk of de-energization, they could receive additional subsequent “Expected” notifications.

De-Energization Notification

When circuits or circuit segments are authorized by the Incident Commander to be de-energized, notifications are sent to all impacted customers, Public Safety Partners and jurisdictions, and are posted on the Public Safety Partner Portal, and on sce.com/outages.

Restoration Phase

Prepare to Restore

Prepare to Restore notifications are sent to all impacted customers and public safety partners as soon as restoration has been authorized. These notifications specify that the process “typically takes up to 8 hours but could take longer if we need daylight for safe inspections”.

Restored In Scope, Restored No Longer in Scope, and Event Concluded

When power is restored, customers are alerted via a PSPS Ended notification. Customers who remain at risk of further de-energization will receive a notification advising them of the continued risk. Jurisdictions are sent an email as each circuit is restored, and a final email at the conclusion of the event within their jurisdiction.

³ Switching efforts include, but are not limited to, sectionalizing lines to minimize the amount of the line that is de-energized, transferring customers from overhead sections of a line to underground sections, or transferring customers to another circuit outside the HFRA or not at risk of de-energization.

Notification Accuracy and Precision

Accuracy and Precision

The Central Data Platform (CDP), launched in 2022, was designed to automate data flows between operations and the notifications teams. Since its implementation, CDP has significantly improved the speed and accuracy of PSPS notifications.

In 2025, enhancements to CDP will further strengthen notification performance. While sudden, unexpected weather events continue to pose challenges, the automation provided by CDP has reduced missed notifications compared to 2021 and earlier seasons, when manual processes were more heavily relied upon.

SCE's decision-making process for PSPS events prioritizes safety. In some cases, emergent weather results in emergency de-energization decisions. These decisions prioritize safety over timely notifications.

SCE continues to make every effort to avoid over-notifying customers during PSPS events, and to inform customers as quickly as possible via cancellation notifications when changing weather conditions remove them from scope. However, factors such as the changing nature of emergent weather and efforts to reduce the number of customers de-energized through switching schemes and real-time weather observations may impact notifications.

Increased Stability of Forecasting

SCE Weather Services is continuing to expand and refine its machine learning forecast capabilities in 2025. SCE will be increasing forecast coverage to up to 1797 locations in its machine learning forecast system driven by its deterministic weather model and at up to 1775 weather station locations when driven by its 1-km ensemble forecast systems. Pre-existing machine learning forecast locations will also be retrained this year based on new observations from 2024 and early 2025.

SCE has also started to utilize machine-learning to bias correct weather station forecasts originating from the NAM public model from its academic research partnership. The addition of this model along with the ensemble-based machine learning in late 2024 brings the total number of unique machine learning forecast systems run by SCE up to a total of five.

SCE has expanded its climatological data sets to provide forecasters information about not only wind criteria exceedance, but also the frequency of different FPI weather scores. This allows forecasters to have a more holistic understanding of PSPS criteria exceedance frequency.

Entity Responsible for Notifications

SCE follows principles of the National Incident Management System and components of the Standardized Emergency Management System during PSPS events. This includes using an Incident Management Team structure to execute PSPS events, assigning an Incident Commander responsible for all de-energization decision-making and coordinating at the Operational Area level during PSPS events. The assigned Incident Commander is responsible for all de-energization and re-energization decisions made during any PSPS event.

All notifications have been consolidated and are implemented by the Notifications Task Force, a subsection of the Operations section within the Incident Management Team.

Consistency of PSPS Notification Information Across All Platforms

Customer Access to PSPS Event Information on SCE.com

SCE continues to provide our customers and communities with access to PSPS information on [SCE.com](https://www.sce.com). The [sce.com/outagemap](https://www.sce.com/outagemap) webpage now provides a search feature and a map to display each circuit under consideration for de-energization or currently de-energized. The website also provides additional information such as anticipated start date and time, anticipated end date and time for the Period of Concern, and a range for estimated restoration date and time. Community Resource Centers and Community Crew Vehicles activation and availability information is also provided on SCE's outage map website.

News and Social Media

SCE reaches out to local media on an ongoing basis to inform them about PSPS and customer resiliency. In the 2025 pre-season, the media relations team contacted approximately 140 reporters across the service area. This continues to result in network coverage about SCE's wildfire mitigation

efforts and grid hardening work to reduce the frequency and scope of PSPS – along with explanations of PSPS, what to expect and how to prepare.

SCE also posts frequently on all platforms to inform customers about PSPS, mitigation efforts, grid hardening and resources. SCE published posts educating customers about wildfire mitigation efforts, targeted undergrounding and wildfire preparedness, garnering over 200,000 impressions. SCE ran targeted social media advertising and organic posts via several platforms to help customers prepare for PSPS events. SCE launched ads in 2024 during PSPS events to promote resources and educate customers on wildfire mitigation efforts, garnering over 32M impressions. The team also monitors social media to escalate customer concerns that are reported via social media.

Direct Mail

SCE publishes PSPS newsletters for all customers annually. In 2025, newsletters were mailed or emailed to all customers. The HFRA version featured wildfire mitigation and PSPS efforts and customer support information, and the version for non-HFRA customers was focused on emergency and outage preparedness. These newsletters encourage customers to prepare for PSPS or other outages by creating a power outage plan, checking their emergency kits, and updating outage notification preferences with SCE. Both versions of the newsletter are also available in the sce.com wildfire communications center, at sce.com/wcc in all prevalent languages.

Advertising

SCE's mass media education campaign features radio, digital (i.e., search, banners, video) and social media advertisements encouraging customers to update their outage alert preference, take advantage of SCE's programs and resources (Medical Baseline Program, Back-up Battery Rebate, etc.) and prepare for emergencies. SCE Corporate Communications tracks campaign metrics and reports them to the CPUC. The 2024 campaign generated a total of 642 million impressions. The year-end campaign awareness was at 55%, above the 2024 goal of 50%.

Phone

Customers can contact SCE representatives directly through the SCE call center. SCE has a special contact number, available 24/7 for emergency/first responders and local government officials. The number is included in all PSPS partner notifications and distributed to appropriate agencies.

Online

Customers can connect directly through social media channels (i.e., Facebook, Twitter, and Instagram) and by visiting the [PSPS web page](#) on SCE.com.

Additional Collateral

Information on SCE's PSPS decision-making process is available to customers in a technical paper, a fact sheet written for general audiences, and a 3-minute animated video. These are available at sce.com/pspsdecisionmaking and are regularly shared with stakeholders through public meetings.

Coordination with Stakeholders

Plans for notifications are shared with stakeholders through pre-existing meetings that take place both year-round, and in advance of fire season.

Community Meetings

SCE regularly conducts community meetings for customers in HFRAs to discuss its Grid Safety and Resiliency Program (GSRP), Wildfire Mitigation Plan (WMP), and PSPS. Since 2020, meetings have been attended remotely, and audiences invited grouped by county. Customers are invited to those meeting by direct mail and paid Facebook ads. In addition, SCE invites first-responders, local government contacts, and community-based organization partners (e.g., American Red Cross and local Fire Safe Councils) to participate. Community meetings, in community-relevant languages, include a presentation and discussion featuring SCE's subject matter experts. There has been a decline in meeting participation likely due to SCE's grid hardening activities and reduction in PSPS events.

SCE regularly engages with local government officials, tribal staff, and first responders to educate stakeholders on its WMP and its potential impact on their community. These meetings focus on educating local and tribal governments about the PSPS de-energization process and how the company will communicate and work with government agencies and emergency operations during outages.

SCE receives input from these meetings and other discussions with local government officials and incorporates the input in its PSPS notifications. SCE conducts these meetings to further enhance

partnerships, increase awareness, and discuss lessons learned. These meetings are tailored for information at a more granular level, specific to the business, organization, or community needs.

Affirmative Notifications to Medical Baseline Populations and Any Self-Identified Vulnerable Populations

SCE takes additional steps to ensure Medical Baseline populations, as well as self-certified sensitive customers, receive PSPS notifications. If there is no affirmative confirmation that the first notification sent through these customers' selected channel(s) was received, a second communication attempt is made. If this second attempt is likewise unsuccessful, Field Service Representatives (FSRs) are dispatched from District Offices to the customer's location. FSRs will knock on customers' doors and leave a doorhanger if direct contact is unsuccessful.

Stakeholder Meetings

SCE meets with key stakeholders to receive input and feedback on PSPS protocols. These meetings include Regional Working Groups (RWG) and a territory-wide Advisory Board (AB). Regionalized Working Groups providing the opportunity for participation from small multi-jurisdictional electric utilities, community choice aggregators (CCAs), publicly owned electric utilities, communications and water service providers, CPUC staff, tribal and local government entities, and representatives of people/communities with access and functional needs (AFN) and vulnerable communities. The AB provides advisory functions regarding issues, opportunities, and challenges related to minimizing the impacts of PSPS. The members consist of Public Safety Partners, communications and water service providers, local and tribal government officials, business groups, non-profit organizations, representatives of AFN people/communities, and academic organizations. Community input from customer service phone calls, emails and social media, and employee debriefs provide additional feedback.

Notification Strategies for Reaching AFN Customers

SCE's Outage Alerts landing page highlights the importance of self-certification. The page features prominent messaging and a link to a self-certification form so customers can notify SCE if any member of their household uses life-sustaining medical equipment or relies on electricity to manage

a medical condition but are not currently enrolled in our Medical Baseline Allowance program. SCE's notification approach includes using accessible language for notifications, leveraging Community Based Organization (CBO) networks to augment SCE's messaging, notifying paratransit agencies as well as owners and managers of multi-family dwellings, providing address level alerts for non-account holders and taking additional steps to ensure MBL and self-certified customers are receiving notifications about potential PSPS.

When possible, SCE notifies community-based organizations that serve individuals with AFN between 48 and 72 hours before a potential PSPS de-energization. Priority notifications allow CBOs to prepare in advance, amplify messaging, and perform safety preparedness checks on their constituents as needed. A daily coordination call is held for these organizations during PSPS activation.

Paratransit agencies are considered critical infrastructure customers and receive priority advance notifications through their preferred channel, including text, email or voice, as early as 72 hours prior to events. Paratransit agencies may also request access to the Public Safety Partner Portal, where they can obtain detailed information about potential PSPS activations, including access to aggregated information on customers served by the circuits being monitored.

SCE will continue to promote Address Level Alerts for non-account holders, which gives sub-metered tenants, property managers, tenants, and any individual with AFN (e.g., out-of-town travelers, caregivers, individuals struggling with homelessness, etc.) access to valuable notifications.⁴

SCE continues to request feedback from local/tribal governments and Public Safety Partners on opportunities to reach management and owners of multi-family properties. AFN population subsets and individually metered multifamily building tenants are also reached through the PSPS Newsletter. SCE also sends out an annual letter requesting landlord/property owners' assistance to educate their sub-metered tenants about PSPS. The letter includes copies of a flyer, in Spanish and English, which can be posted on the property.

⁴ SCE conducts outreach to multi-family building account holders, building managers and tenants to provide education on PSPS notifications and programs that offer resiliency support. See D.21.06.034, Appendix A at A9.

Public Warning of PSPS Events Such as Week-Ahead Forecasts

The PSPS weather awareness page, sce.com/weather-awareness, provides a week-ahead forecast by county to indicate potential for PSPS weather.

During the normal phase of operations, SCE maintains sce.com/weather-awareness and monitors forecasts for potential upcoming events.

Notification Cancellation

SCE makes every attempt to provide notification of the cancellation of a PSPS event, or removal from scope, by notifying all affected entities, including public safety partners, within two hours of the decision to cancel.

Transmission-Level Customer Notification

SCE sends annual communications and hosts workshops for transmission level customers to educate them about PSPS.

When transmission level customers are in scope for PSPS, dedicated account managers will notify these customers directly. Whenever possible, the account manager will provide a priority notification at least 48-72 hours in advance of de-energization event and will also provide notification to a transmission-level customer to the extent possible within two hours after it has begun surveying de-energized lines. SCE is planning to automate the transmission-level customer communication as part of the updated Central Data Platform process.

Impacted Customer Information Available to Public Safety Partners, Critical Facilities and Critical Infrastructure from Outset of PSPS

To the extent feasible, SCE notifies Public Safety Partners and Critical Facilities and Critical Infrastructure according to the notification cadence in Table 1: Notification Details. Critical Infrastructure notifications provide meter information, rate and facilities in scope for impacted

customers. Public Safety Partner “Advanced Initial” notifications include links to the Public Safety Partner Portal where additional password protected customer information and maps and shapefiles can be found. SCE continues to provide meter data during events on the Public Safety Partner Portal to Public Safety Partners with elevated access.

Secure Portal for Public Safety Partners

SCE's Public Safety Partner Portal, launched in 2021, offers public safety partners and critical facilities and infrastructure customers PSPS emergency information including planning data to be used ahead of PSPS events, as well as in-event PSPS data to be accessed for near real-time information related to the event.

SCE's annual portal re-certification process is conducted yearly. Portal enhancements based on user needs are identified from Public Safety Partner Portal office hours and other outreach to Public Safety Partners.

Registered users of the Public Safety Portal can access key resources, including circuit information, customer profile summaries, and GIS files, to support planning and response efforts. During Public Safety Power Shutoff (PSPS) events, SCE also provides maps to Public Safety Partners through its REST service.

Lessons Learned

SCE has included lessons learned in Table 14 in the PSPS Pre-Season Tables are located in Appendix F.

Attachment A

Notification Templates/Scripts

**PSPS Variable Notification Templates - Local/Tribal Governments and Community Based
Organizations (CBOs) Working Within the Access and Functional Needs (AFN)
Community**

Template Language for All Notifications (After Notification Language)

SCE Emergency Operations Center and IMT are activated. Contact information is provided below.

Message cadence: *The SCE Liaison Officer provides a rolling three-day advance warning of potential PSPS events, when possible, and sends update notifications every day. We will also notify you with time-sensitive shutoff and restoration information at the circuit level. Sudden weather changes may impact SCE's ability to provide advanced notice: a shutoff could occur sooner than anticipated.*

Spreadsheet content: *All circuits currently on the watch list in your county are listed in the attached spreadsheet. As we get closer to the event and the weather forecast becomes more exact, additional circuits could be added or removed from our watch lists. Definitions are on the second tab of the spreadsheet.*

Not all circuits on the watch list will have their power shut off. We are working to reduce the number of customers affected and weather patterns might change.

Customers on the affected circuits are being notified if they are within two days of the period of concern, or if there has been a change to their status.

Outage maps and other detailed information are available at the following locations:

- Maps showing PSPS boundaries and locations of about Community Resource Centers and Community Crew Vehicles: <https://www.sce.com/outage-center/check-outage-status>
- Public Safety Partner Portal (for emergency officials)
 - <https://publicsafetyportal.sce.com/>
 - Email publicsafetyportal@sce.com to request access.
- REST service (web-based password-protected access to GIS layers)
 - SCERestInfo@sce.com to request access.

SCE Contact Information for Public Officials only (DO NOT share with the public)

- **First Responders and Emergency Managers:**
 - Phone: Business Resiliency Duty Manager 24/7 hotline: (800) 674-4478
 - Email: Business Resiliency Duty Manager/emergencies:
BusinessResiliencyDutyManager@sce.com **Note: Only monitored during emergency activations.**
- **Government/tribal officials:**

- Phone Liaison (government relations) 24/7 hotline: 800-737-9811. **Note: Only monitored during emergency activations.**
- Email SCELiaisonOfficer@sce.com. **Note: Only monitored during emergency activations.**
- **Access and Functional Needs issues:**
 - Phone AFN Liaison Officer 24/7 hotline: 888-588-5552. **Only monitored during emergency activations.**
 - Email: AFNIMT@sce.com. **Note: Only monitored during emergency activations.**

Information available for the general public:

- **SCE Contact Information for the Public: (Please share via web and social media).**
 - Outage specific customer service issues: 800-611-1911
 - Billing and service inquiries: 800-684-8123
- Maps showing PSPS boundaries and locations of about Community Resource Centers and Community Crew Vehicles: <https://www.sce.com/outage-center/check-outage-status>
- General information on PSPS: www.sce.com/psps
- De-energization and restoration policies: sce.com/pspsdecisionmaking
- Information on emergency preparedness, customer notifications, customer programs and other resources: www.sce.com/wildfire
- Seven-day PSPS forecasts <https://www.sce.com/wildfire/weather-awareness>
- Fire and weather detection map <https://www.sce.com/wildfire/situational-awareness>

Advanced Initial (72-hour) LNO Notification (Advanced Initial)

Text Language: Important: SCE Advanced Initial Notice for PSPS Event in {County} CO on {Start POC Date}. Please see your inbox for more details.

Email Notification Subject Line and Message

Advanced Initial Notice for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time] .

COMMENTS:

Public Safety Power Shutoff initial notification for official use: Due to projected fire weather conditions, we may need to shut off power in high fire risk areas in {COUNTY NAME}. Please refer to the attached spreadsheet for status and periods of concern for specific circuits.

Recommended Language to Share with the Public: SCE has informed us they may be calling for a Public Safety Power Shutoff impacting (insert organization name) on (insert date). SCE will notify all

customers who may be affected, including Critical Care and Medical Baseline customers. For more info: [sce.com/psps](https://www.sce.com/psps)

When the weather improves, and restoration is authorized, crews will inspect and repair the lines and restore power. Typically, this can take up to 8 hours. Restoration can be delayed if damage is found, or daylight is needed for safe aerial or ground patrol. Updates to restoration information will be posted on www.sce.com/psps and on the Public Safety Partner Portal.

Updated Conditions (Update) Notification

Text Language: Important: SCE Update/Initial Notice for PSPS Event in {County} CO. Please see your inbox for more details.

Notification Subject Line and Message:

SCE Update/Initial Notice for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time] .

COMMENTS:

Public Safety Power Shut-Off update notification for official use:

Due to projected fire weather conditions, we may need to shut off power in high fire risk areas, in {COUNTY NAME}. Please refer to the attached spreadsheet for status and periods of concern for specific circuits.

Recommended Language to Share with the Public: SCE has informed us there may be a Public Safety Power Shutoff impacting (insert organization name) on (insert date). SCE will notify all customers who may be affected, including Critical Care and Medical Baseline customers. For more info: [sce.com/psps](https://www.sce.com/psps)

When the weather improves, and restoration is authorized, crews will inspect and repair the lines and restore power. Typically, this can take up to 8 hours. Restoration can be delayed if damage is found, or daylight is needed for safe aerial or ground patrol. Updates to restoration information will be posted on www.sce.com/psps and on the Public Safety Partner Portal.

Expected De-Energize Notification (previously: Imminent De-Energization) (PSPS Expected)

Text Language: Important: SCE Expected Shutoff Notice for PSPS Event on {Circuit(s)} Circuit in {County} CO. Please see your inbox for more details.

Email Notification Subject Line and Message:

SCE Expected Shutoff Notice for [CIRCUIT NAME] Circuit for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time] .

Public Safety Power Shutoff update notification for official use: SCE may need to shut off power in the next 4 hours to reduce the risk of wildfire ignition. Areas that may be impacted include:

- **Circuit:** [CIRCUIT name]
- **County:**
- **Segment:** [if listed]
- **Incorporated City of:**
- **Unincorporated County Area:**
- **COMMENTS:**

Shutoffs may occur earlier or later depending on actual weather conditions. This notice expires after 4 hours; however, the listed circuit(s) will remain on the watch list and will be subject to PSPS until the conclusion of this weather event.

Recommended Language to Share with the Public: SCE has informed us they are likely to call a Public Safety Power Shutoff impacting (insert organization name) within the next four hours. SCE will notify all customers who may be affected. For more info: [sce.com/psps](https://www.sce.com/psps)

When the weather improves, and restoration is authorized, crews will inspect and repair the lines and restore power. Typically, this can take up to 8 hours. Restoration can be delayed if damage is found, or daylight is needed for safe aerial or ground patrol. Updates to restoration information will be posted on www.sce.com/psps and on the Public Safety Partner Portal.

PSPS Shutoff Notification (De-energization notification)

Text Language: Important: SCE PSPS Shutoff Notice for {Circuit(s)} Circuit in {County} CO. Please see your inbox for more details.

Email Notification Subject Line and Message:

SCE PSPS Shutoff Notice for [CIRCUIT NAME] Circuit for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time].

Public Safety Power Shutoff update notification for official use: SCE is shutting off power to reduce the risk of wildfire ignition.

Impacted circuits and locations are:

- **Circuit:** [CIRCUIT name]
- **County:** [COUNTY NAME].
- **Segment:**
- **Incorporated City of:** [Incorporated City]
- **Unincorporated County Area:** [unincorporated area description]
- **Comment:**

Recommended Language to Share with the Public: SCE has begun a Public Safety Power Shutoff. SCE notified customers who may be affected, including Critical Care and Medical Baseline customers. For more information visit [sce.com/psps](https://www.sce.com/psps)

When the weather improves, crews will inspect and repair the lines and restore power. When the weather improves, and restoration is authorized, crews will inspect and repair the lines and restore power. Typically, this can take up to 8 hours. Restoration can be delayed if damage is found, or daylight is needed for safe aerial or ground patrol. Updates to restoration information will be posted on www.sce.com/psps and on the Public Safety Partner Portal.

Preparation for Restoration

Text Language: Important: SCE Preparation for Restoration {Circuit(s)} Circuit in {County}. Please see your inbox for more details.

Email Notification Subject Line and Message:

Preparation for Restoration [CIRCUIT NAME] Circuit Shutoff Notice for [CIRCUIT NAME] Circuit for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time].

Public Safety Power Shutoff update notification for official use: SCE crews are inspecting the following circuits or circuit segments to restore power as soon as it is safe to do so:

- **Circuit:** [CIRCUIT name]
- **Segment(s):** if entered in Foundry
- **Incorporated City:** [incorporated city]

- **Unincorporated County Area:** [unincorporated area description]
- **Comments:**

Recommended Language to Share with the Public: SCE has begun patrolling circuits for damage before turning the power back on. It typically takes up to 8 hours to restore power once the patrol begins. Restoration can be delayed if damage is found, or aerial patrol is needed. For more info visit [sce.com/psps](https://www.sce.com/psps)

When the weather improves, and restoration is authorized, crews will inspect and repair the lines and restore power. Typically, this can take up to 8 hours. Restoration can be delayed if damage is found, or daylight is needed for safe aerial or ground patrol. Updates to restoration information will be posted on www.sce.com/psps and on the Public Safety Partner Portal.

Restore Notification (formerly: RE-ENERGIZE) Restoration Notification

Text Language: Important: SCE Restoration Notice for PSPS Event on {Circuit(s)} Circuit in {County} CO. Please see your inbox for more details.

Email Notification Subject Line and Message:

Important: SCE Restoration Notice for PSPS Event on [CIRCUIT NAME] Circuit Shutoff Notice for [CIRCUIT NAME] Circuit for PSPS Event starting [start POC DATE] in [COUNTY NAME] as of [current date] [current time].

Public Safety Power Shutoff update notification for official use:

SCE crews have restored power on the following circuit or circuit segments:

- **Circuit:** [CIRCUIT name]
- **Segment(s):** if entered in Foundry
- **Incorporated City:** [incorporated city]
- **Unincorporated County Area:** [unincorporated area description]
- **Comment:**

Recommended Language to Share with the Public: SCE has begun turning power back on to circuits. Some areas may be restored sooner than others. For more info visit [sce.com/psps](https://www.sce.com/psps)

Cancellation No Longer in Scope

Description: Sent within two hours after a circuit no longer in scope for PSPS

Text Language Important: SCE PSPS Cancellation {Circuit(s)} Circuit in {County} CO. Please see your inbox for more details.

Notification Subject Line and Message:

Important: SCE PSPS Cancellation as of {LNO Authorized Date} {LNO Authorized Time} for PSPS Event {Start POC Date} {Circuit(s)} Circuit in {County} CO.

Public Safety Power Shutoff update notification for official use: Due to improved conditions SCE is no longer planning to shut off power the circuit listed below.

- **Circuit:** [CIRCUIT name]
- **County:**
- **Segment:** [if listed]
- **Incorporated City of:**
- **Unincorporated County Area:**

Language to share with the public: Some customers in our area are no longer in scope for public safety power shutoffs. Check sce.com/outages for more information.

Event Concluded Notification

Text Language Important: SCE PSPS Event Concluded in {County} CO. Please see your inbox for more details.

Email Notification Subject Line and Message:

SCE PSPS Event Concluded in [COUNTY NAME].

Public Safety Power Shutoff update notification for official use:

If customers were de-energized, power has been restored and the PSPS event has concluded.

Recommended Language to Share with the Public: The public safety power shutoff in your area has concluded. If your power is still out, please visit sce.com/outages for more information.

Any circuit that was identified for potential PSPS is All Clear and will not be de-energized for this event

PSPS Variable Notification Templates - Customer

Advanced Initial

(Typically, 72 Hours Prior)

Only for Public Safety Partners (Telecom/Water-Wastewater) and Critical Infrastructure

TEXT/SMS

SCE Advanced PSPS Alert: High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/ evening^. We may have to shut off power. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected, and weather patterns might change, so not all notified customers will have their power shut off. For the latest updates, visit publicsafetyportal.sce.com, contact your assigned SCE account representative, or call 1-800-611-1911.

VOICE

SCE Advanced Public Safety Power Shutoff Alert: High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/ evening^. We may have to shut off power. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected, and weather patterns might change, so not all notified customers will have their power shut off. For the latest updates visit [publicsafetyportal dot sce dot com](https://publicsafetyportal.sce.com), contact your assigned SCE account representative, or call 1-800-611-1911

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) Advanced Initial Alert - ^approved date and time^
From: do_not_reply@scwebseervices.com Southern California Edison

High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may need to shut off power to decrease the risk of dangerous wildfires. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected, and weather patterns might change, so not all notified customers will have their power shut off.

This alert applies to the following address(es):

Customer Address
Service Account
Meter Number
Rate

For the latest updates and availability of community resources, visit <https://publicsafetyportal.sce.com/> if you are registered, contact your assigned SCE account representative, or call 1-800-611-1911.

Initial Notification Alert

(48 Hours Before)

TEXT/SMS

SCE PSPS Alert: High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk during this time. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected and will keep you updated. Visit sce.com/psps for the latest information. For downed power lines, call 911. View in more languages: www.sce.com/PSPSInitial or view in ASL: <https://ahas.sce.com?id=psps1>

VOICE

SCE Public Safety Power Shutoff Alert. To continue in English, press 1. [Spanish press 2], all other languages press 3.... High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected and will keep you updated. Visit sce dot com slash psps for the latest information. If you see a downed power line call 911.

EMAIL

Subject: SCE Public Safety Power Shutoff Alert - ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

High winds and dangerous fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers whose power will be shutoff and will keep you updated. For the latest updates, outage map, and information about customer care services, visit sce.com/psps.

Thank you for your patience as we work to keep your community safe!

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

- For information about preparing for a power outage, visit sce.com/safety/family/emergency-tips.
- REMEMBER: If you see a downed power line, call 911 first and then notify SCE at 1-800-611-1911.

Update Notification Warning

(24 Hours Before)

TEXT/SMS

SCE PSPS Warning: High winds and fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of wildfires. We are working to reduce the number of customers affected and will keep you updated. Visit sce.com/psps for the latest information and availability of community resources. For downed power lines, call 911. View in more languages: www.sce.com/PSPSUpdate or view in ASL: <https://ahas.sce.com?id=psps2>

VOICE

SCE Public Safety Power Shutoff warning. To continue in English, press 1. [Spanish press 2], all other languages press 3.... High winds and dangerous fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of wildfires. We are working to reduce the number of customers whose power will be shutoff and will keep you updated. Visit [sce dot com slash psps](https://sce.com/psps) for the latest information and availability of community resources. If you see a downed power line call 911.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) Warning – ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

High winds and dangerous fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. We are working to reduce the number of customers whose power will be shut off and will keep you updated. For the latest updates, outage map, and availability of community resources, visit sce.com/psps.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

- For information about preparing for a power outage, visit sce.com/safety/family/emergency-tips.
- REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911.

Thank you for your patience as we work to keep your community safe!

Cancellation

(Sent at any time when customer is permanently out of scope)

TEXT/SMS

SCE PSPS All-Clear: Due to improved weather, we did not shut off your power. We understand that planning around outages is inconvenient. Thanks for your patience as we work to keep our communities safe. If your power is off, please call 1-800-611-1911 or visit sce.com/psps. View in more languages: www.sce.com/PSPSAIIClear or view in ASL: <https://ahas.sce.com?id=psps3>

VOICE

SCE PSPS All-clear: To continue in English, press 1. [Spanish press 2], all other languages press 3.... Due to improved weather, we did not shut off your power. We understand that planning around

outages is inconvenient. Thank you for your patience as we work to keep our communities safe. If your power is off, please call 1-800-611-1911 or visit [sce dot com slash psps](http://sce.com/psps).

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) All-clear – ^approved date and time^

From: do_not_reply@scewebservices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

[1-800-441-2233](#)

[한국어](#)

[1-800-628-3061](#)

[中文](#)

[1-800-843-8343](#)

[TIẾNG VIỆT](#)

[1-800-327-3031](#)

[TAGALOG](#)

[1-800-655-4555](#)

[MORE LANGUAGES](#)

[View in ASL](#)

Due to improved weather, we did not shut off your power. We understand that planning around outages is inconvenient. Thank you for your patience as we work to keep our communities safe.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

If power is off, please call 1-800-611-1911 or visit sce.com/psps.

For more information about PSPS and wildfire safety, please visit sce.com/psps.

PSPS Expected

(1-4 Hours Before Shutoff Warning)

TEXT/SMS

SCE PSPS Expected: It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We will notify you again if we shut power off. Weather could affect shutoff timing and wind-related outages may also occur. Visit sce.com/psps for the latest information and availability of community resources. For downed power lines, call 911. Thanks for your patience. View in more languages: www.sce.com/PSPSExpected or view in ASL: <https://ahas.sce.com?id=psps4>

VOICE

SCE PSPS Expected. To continue in English, press 1. [Spanish press 2], all other languages press 3.... It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions in your area. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We will notify you again if we shut off your power. Weather could affect shutoff timing and wind-related outages may also occur. Visit sce dot com slash psps for the latest information and availability of community resources. If you see a downed power line, call 911. Thank you for your patience.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) Expected – ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We are working to reduce the number of customers affected. Weather could also affect shutoff timing and wind-related outages may occur. We will notify you again if we shut off your power. For the latest updates, outage map, and availability of community resources, visit sce.com/psps.

We appreciate your patience as we work to keep your community safe.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

- For information about preparing for a power outage, visit [sce.com/safety/family/emergency-tips](https://www.sce.com/safety/family/emergency-tips)
- REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911.

Thank you again for your continued patience as we work to keep your community safe!

PSPS Shutoff

(Sent At Authorization to De-Energize)

SMS/TEXT

SCE PSPS Shutoff: We are shutting off your power due to wind-driven wildfire risk. High winds are forecast through ^End Day of week^ ^morning/ afternoon/ evening^. When weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit [sce.com/psps](https://www.sce.com/psps) for the most up to date info on restoration timing and SCE community resources in your area. Remember to turn off/unplug appliances or equipment that could restart automatically. For downed power lines, call 911. Thanks for your patience. View in more languages: www.sce.com/PSPSShutoff or view in ASL: <https://ahas.sce.com?id=psps5>

VOICE

SCE PSPS shutoff. To continue in English, press 1. [Spanish press 2], all other languages press 3.... We are shutting off your power due to current wind-driven wildfire risk. High winds are forecast through ^End Day of week^ ^morning/ afternoon/ evening^. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Remember to turn off or unplug appliances or equipment that could restart automatically. Visit sce dot com slash psps for the latest information on restoration timing and SCE community resources in your neighborhood. If you see a downed power line, call 911. Thank you for your patience.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) - ^approved date and time^
From: do_not_reply@scwebseervices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

We are shutting off your power due to current high risk of wind-driven wildfire. High winds are forecast to last through **^End Day of week^ ^morning/ afternoon/ evening^**. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. We will update you as conditions change. Please remember to turn off or unplug appliances or equipment that may start automatically when power is restored.

Please visit sce.com/psps for the most up to date information, including outage map and restoration information, and availability of SCE community resources.

REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911. We understand this shutoff is inconvenient. We appreciate your continued patience as we work to keep your community safe.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

Continued Shutoff - Next Day Shutoff Update

(Sent in the AM to Overnight Outages)

SMS/TEXT

SCE Continued PSPS Shutoff: Thank you for your continued patience during this Public Safety Power Shutoff. High winds could continue through **^End Day of week^ ^morning /afternoon/ evening^**. Before we restore power, we will inspect our lines for damage. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit sce.com/psps for the latest info on restoration and SCE community resources in your area. For downed power lines, call 911. View in more languages: www.sce.com/PSPSContinuedShutoff or view in ASL: <https://ahas.sce.com?id=psps6>

VOICE

SCE Continued PSPS. To continue in English, press 1. [Spanish press 2], all other languages press 3.... Thank you for your continued patience during this Public Safety Power Shutoff. High winds are forecast to continue through ^End Day of week^ ^morning /afternoon/ evening^. Before we restore power, we will inspect our lines for damage. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit [sce dot com slash psps](http://sce.com/psps) for the latest information on restoration and availability of community resources in your area. For downed power lines, call 911.

EMAIL

Subject: SCE Continued Public Safety Power Shutoff (PSPS) - ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

Thank you for your continued patience during this Public Safety Power Shutoff. Wind-driven fire conditions could last through ^End Day of week^ ^morning /afternoon/ evening^. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit sce.com/psps for the latest information on restoration and SCE community resources in your area. We understand that any outage is an inconvenience. Thank you again for your continued patience as we work to keep your community safe!

REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

Prepare for Restoration

SMS/TEXT

SCE PSPS Update: Winds have died down and we are starting to inspect our lines for damage. Restoration is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or find damage. For updated restoration estimates in your area and for location of SCE community resources visit [sce.com/psps](https://www.sce.com/psps). Please turn off/unplug appliances or equipment that could restart automatically and inspect your property for downed power lines. Call 911 if you find a downed line. We will alert you again when we restore power. View in more languages: www.sce.com/PSPSPrepRestore or view in ASL: <https://ahas.sce.com?id=psps7>

VOICE

SCE PSPS Update. To continue in English, press 1. [Spanish press 2], all other languages press 3.... Winds have died down and we are starting to inspect our lines for damage. Restoration is expected to take up to 8 hours but could be delayed if we need daylight for safe inspections or if we find damage. Please turn off or unplug any appliances or equipment that could restart automatically and inspect your property for downed power lines. Call 911 if you find a downed line. We will alert you again when we restore power. For updated restoration estimates in your area, and for location of SCE community resources visit sce dot com slash psps

EMAIL

Subject: SCE Public Safety Power Shutoff Update - ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

[1-800-441-2233](tel:1-800-441-2233)

[한국어](#)

[1-800-628-3061](tel:1-800-628-3061)

[中文](#)

[1-800-843-8343](tel:1-800-843-8343)

[TIẾNG VIỆT](#)

[1-800-327-3031](tel:1-800-327-3031)

[TAGALOG](#)

[1-800-655-4555](tel:1-800-655-4555)

[MORE LANGUAGES](#)

[View in ASL](#)

Winds have died down and we are starting to inspect our lines for damage. Restoration is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. For updated restoration estimates in your area, and for location of SCE community resources visit [sce.com/psps](https://www.sce.com/psps). We will alert you again when your power comes back on. Please turn off or unplug any appliances or equipment that could restart automatically and inspect your property for downed power lines. If you see a downed power line, stay away and call 911 first, then report it to SCE at 1-800-611-1911.

We understand that Public Safety Power Shutoff events can be disruptive and thank you for your patience as we work to keep your community safe.

This alert applies to the following address(es):

[Customer Address](#)

Service Account
Meter Number
Rate

Restored No Longer in Scope

(Restored & Cancellation No More Risk of PSPS)

SMS/TEXT

SCE PSPS Ended: We have restored power in your area and ended the Public Safety Power Shutoff. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage. We know that safety outages are inconvenient and thank you for your patience. View in more languages: www.sce.com/PSPSEnded or ASL: <https://ahas.sce.com?id=psps10>

VOICE

SCE PSPS Ended... To continue in English, press 1. [Spanish press 2], all other languages press 3... We have restored power in your area and ended the Public Safety Power Shutoff due to improved weather conditions. If your power is still off, please call 1-800-611-1911 or visit sce dot com slash outage. We understand that safety outages are inconvenient and thank you for your patience.

EMAIL

Subject: SCE Public Safety Power Shutoff Ended: All Power Restored – ^approved date and time^
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

We have restored power and ended the Public Safety Power Shutoff in your area due to improved weather conditions. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage. We understand that safety outages are inconvenient and thank you for your patience.

This alert applies to the following address(es):

Customer Address
Service Account
Meter Number
Rate

For more information about PSPS and wildfire safety, please visit sce.com/psps.

Restored in Scope – Risk of PSPS Remains

SMS/TEXT

SCE PSPS Update: Winds have improved enough for us to restore power in your area. However, because high winds are still forecast through **^End Day of week^ ^morning/afternoon/evening^** we might have to shut off power again. We will update you as weather conditions change. If your power is still off, please call 1-800-611-1911 or visit sce.com/psps. Thanks for your patience. View in more languages: www.sce.com/PSPSNotAllClear or view in ASL: <https://ahas.sce.com?id=psps11>

VOICE

SCE PSPS Update: To continue in English, press 1. [Spanish press 2], all other languages press 3.... Winds have improved enough for us to restore power in your area. However, because high winds are still forecast through **^End Day of week^ ^morning/afternoon/evening^** we may have to shut off your power again. We will keep you updated as weather conditions change. We understand that PSPS outages are inconvenient and thank you for your patience. If your power is still off, please call 1-800-611-1911 or visit [sce dot com slash psps](https://sce.com/psps).

EMAIL

Subject: SCE Public Safety Power Shutoff Update: Power restored; PSPS still in effect – **^approved date and time^**

From: do_not_reply@scewebservices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

[한국어](#)

[中文](#)

[TIẾNG VIỆT](#)

[TAGALOG](#)

1-800-441-2233

1-800-628-3061

1-800-843-8343

1-800-327-3031

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

Winds have improved enough for us to restore power in your area. However, because high winds are still forecast through **^End Day of week^ ^morning/afternoon/evening^** we may have to shut off your power again. We will keep you updated as weather conditions change. If your power is still off, please call 1-800-611-1911 or visit sce.com/psps.

We understand that safety outages are inconvenient and thank you for your continued patience.

This alert applies to the following address(es):

Customer Address

Service Account

Meter Number

Rate

For more information about PSPS and wildfire safety, please visit sce.com/pmps.

Address Level Alerts Notification Templates

TEXT HIGHLIGHTED IN YELLOW ARE DYNAMIC VARIABLES

TEXT HIGHLIGHTED IN GREEN REPRESENT CHANGES FROM STANDARD PSPS TEMPLATES

Initial Notification Alert

48 Hours Before

TEXT/SMS

SCE PSPS Alert: High winds and fire conditions are forecast for ^address^ from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected and will keep you updated. Visit sce.com/psps for the latest information. For downed power lines, call 911. View in more languages: www.sce.com/PSPSInitial or view in ASL: <https://ahas.sce.com?id=psps1>. To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE Public Safety Power Shutoff Alert. High winds and fire conditions are forecast for ^address^ from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers affected and will keep you updated. Visit [sce dot com slash psps](http://sce.com/psps) for the latest information. If you see a downed power line call 911. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff Alert
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

High winds and dangerous fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. Power restoration typically takes 8 hours, and will start after the wind subsides. Delays may occur if daylight is required for safe inspections. We are working to reduce the number of customers whose power will be shutoff and will keep you updated. For the latest updates, outage map, and information about customer care services, visit sce.com/psps.

Thank you for your patience as we work to keep your community safe!

This alert applies to the following address:

^address^

- For information about preparing for a power outage, visit sce.com/safety/family/emergency-tips.
- REMEMBER: If you see a downed power line call 911 first and then notify SCE at 1-800-611-1911.

Update Notification Warning

24 Hours Before

TEXT/SMS

SCE PSPS Warning: High winds and fire conditions are forecast for ^address^ from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of wildfires. We are working to reduce the number of customers affected and will keep you updated. Visit sce.com/psps for the latest information and availability of community resources. For downed power lines, call 911. View in more languages: www.sce.com/PSPSUpdate or view in ASL: <https://ahas.sce.com?id=psps2> To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE Public Safety Power Shutoff warning. High winds and dangerous fire conditions are forecast for ^address^ from ^Day of week^ ^morning/afternoon/evening^ through ^End Day of week^ ^morning/afternoon/ evening^. We may have to shut off your power to decrease risk of wildfires. We are working to reduce the number of customers whose power will be shutoff and will keep you updated. Visit sce dot com slash psp for the latest information and availability of community resources. If you see a downed power line call 911. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) Warning
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

High winds and dangerous fire conditions are forecast from ^Day of week^ ^morning/afternoon/evening^ through ^End day of week^ ^morning/afternoon/evening^. We may have to shut off your power to decrease risk of dangerous wildfires. We are working to reduce the number of customers whose power will be shut off and will keep you updated. For the latest updates, outage map, and availability of community resources, visit sce.com/psps.

This alert applies to the following address:

^address^

- For information about preparing for a power outage, visit sce.com/safety/family/emergency-tips.
- REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911.

Thank you for your patience as we work to keep your community safe!

Cancellation

Sent At Any Time When Customer is Permanently Out Of Scope

TEXT/SMS

SCE PSPS All-Clear: Due to improved weather, we did not shut off your power for ^address^. We understand that planning around outages is inconvenient. Thanks for your patience as we work to keep our communities safe. If your power is off, please call 1-800-611-1911 or visit sce.com/psps. View in more languages: www.sce.com/PSPSAIIClear or view in ASL: <https://ahas.sce.com?id=psps3>
To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE PSPS All-clear. Due to improved weather, we did not shut off your power for ^address^. We understand that planning around outages is inconvenient. Thank you for your patience as we work to keep our communities safe. If your power is off, please call 1-800-611-1911 or visit sce dot com slash psps. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) All-clear

From: do_not_reply@scewebservices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

Due to improved weather, we did not shut off your power. We understand that planning around outages is inconvenient. Thank you for your patience as we work to keep our communities safe.

This alert applies to the following address:

^address^

If power is off, please call 1-800-611-1911 or visit sce.com/psps.

For more information about PSPS and wildfire safety, please visit sce.com/psps.

PSPS Expected Warning

1-4 Hours Before Shutoff

TEXT/SMS

SCE PSPS Expected: It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions for ^address^. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We will notify you again if we shut power off. Weather could affect shutoff timing and wind-related outages may also occur. Visit sce.com/psps for the latest information and availability of community resources. For downed power lines, call 911. Thanks for your patience. View in more languages: www.sce.com/PSPSExpected or view in ASL: <https://ahas.sce.com?id=psps4> To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE PSPS Expected. It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions for ^address^. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We will notify you again if we shut off your power. Weather could affect shutoff timing and wind-related outages may also occur. Visit sce dot com slash psps for the latest information and availability of community resources. If you see a downed power line, call 911. Thank you for your patience. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS) Expected
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

It's likely we will shut off your power in the next 4 hours due to wind-driven fire conditions. Conditions could last through ^End Day of week^ ^morning /afternoon /evening^. We are working to reduce the number of customers affected. Weather could also affect shutoff timing and wind-related outages may occur. We will notify you again if we shut off your power. For the latest updates, outage map, and availability of community resources, visit sce.com/psps.

We appreciate your patience as we work to keep your community safe.

This alert applies to the following address:

^address^

- For information about preparing for a power outage, visit sce.com/safety/family/emergency-tips

- REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911.

Thank you again for your continued patience as we work to keep your community safe!

PSPS Shutoff

Sent At Authorization To De-Energize

SMS/TEXT

SCE PSPS Shutoff: We are shutting off your power for ^address^ due to wind-driven wildfire risk. High winds are forecast through ^End Day of week^ ^morning/ afternoon/ evening^. When weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit [sce.com/psps](https://www.sce.com/psps) for the most up to date info on restoration timing and SCE community resources in your area. Remember to turn off/unplug appliances or equipment that could restart automatically. For downed power lines, call 911. Thanks for your patience. View in more languages: www.sce.com/PSPSShutoff or view in ASL: <https://ahas.sce.com?id=psps5>. To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE PSPS shutoff. We are shutting off your power for ^address^ due to current wind-driven wildfire risk. High winds are forecast through ^End Day of week^ ^morning/ afternoon/ evening^. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Remember to turn off or unplug appliances or equipment that could restart automatically. Visit sce dot com slash psps for the latest information on restoration timing and SCE community resources in your neighborhood. If you see a downed power line, call 911. Thank you for your patience. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff (PSPS)

From: do_not_reply@scwebservices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

We are shutting off your power due to current high risk of wind-driven wildfire. High winds are forecast to last through ^End Day of week^ ^morning/ afternoon/ evening^. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. We will update you as conditions change. Please remember to turn off or unplug appliances or equipment that may start automatically when power is restored.

Please visit sce.com/psps for the most up to date information, including outage map and restoration information, and availability of SCE community resources.

REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911. We understand this shutoff is inconvenient. We appreciate your continued patience as we work to keep your community safe.

This alert applies to the following address:

^address^

Continued Shutoff - Next Day Shutoff Update

Sent In The Am To Overnight Outages

SMS/TEXT

SCE Continued PSPS Shutoff: Thank you for your continued patience during this Public Safety Power Shutoff. High winds could continue through ^End Day of week^ ^morning /afternoon/ evening^. Before we restore power for ^address^, we will inspect our lines for damage. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit sce.com/psps for the latest info on restoration and SCE community resources in your area. For downed power lines, call 911. View in more languages: www.sce.com/PSPSContinuedShutoff or view in ASL: <https://ahas.sce.com?id=psps6>. To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE Continued PSPS. Thank you for your continued patience during this Public Safety Power Shutoff. High winds are forecast to continue through ^End Day of week^ ^morning /afternoon/ evening^. Before we restore power for ^address^, we will inspect our lines for damage. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit sce dot com slash psps for the latest information on restoration and availability of community resources in your area. For downed power lines, call 911. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Continued Public Safety Power Shutoff (PSPS)

From: do_not_reply@scewebseervices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

[ESPAÑOL](#)

1-800-441-2233

[한국어](#)

1-800-628-3061

[中文](#)

1-800-843-8343

[TIẾNG VIỆT](#)

1-800-327-3031

[TAGALOG](#)

1-800-655-4555

[MORE LANGUAGES](#)

[View in ASL](#)

Thank you for your continued patience during this Public Safety Power Shutoff. Wind-driven fire conditions could last through **^End Day of week^ ^morning /afternoon/ evening^**. When the weather improves, we will inspect our lines for damage before we restore power. This is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. Visit sce.com/psps for the latest information on restoration and SCE community resources in your area. We understand that any outage is an inconvenience. Thank you again for your continued patience as we work to keep your community safe!

REMEMBER: If you see a downed power line, call 911 first, and then notify SCE at 1-800-611-1911. This alert applies to the following address:

^address^

Prepare For Restoration

SMS/TEXT

SCE PSPS Update: Winds have died down and we are starting to inspect our lines for damage. **We are working to restore power for ^address^**. Restoration is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or find damage. For updated restoration estimates in your area and for location of SCE community resources, visit sce.com/psps. Please turn off/unplug appliances or equipment that could restart automatically and inspect your property for downed power lines. Call 911 if you find a downed line. We will alert you again when we restore power. View in more languages: www.sce.com/PSPSPrepRestore or view in ASL: <https://ahas.sce.com?id=psps7> **To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.**

VOICE

SCE PSPS Update. Winds have died down and we are starting to inspect our lines for damage. **We are working to restore power for ^address^**. Restoration is expected to take up to 8 hours but could be delayed if we need daylight for safe inspections or if we find damage. Please turn off or unplug any appliances or equipment that could restart automatically and inspect your property for downed power lines. Call 911 if you find a downed line. We will alert you again when we restore power. For updated restoration estimates in your area and for location of SCE community

resources visit sce dot com slash psp. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff Update

From: do_not_reply@scewebservices.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

Winds have died down and we are starting to inspect our lines for damage. Restoration is expected to take up to 8 hours but could take longer if we need daylight for safe inspections or if we find damage. For updated restoration estimates in your area, and for location of SCE community resources visit sce.com/psps. We will alert you again when your power comes back on. Please turn off or unplug any appliances or equipment that could restart automatically and inspect your property for downed power lines. If you see a downed power line, stay away and call 911 first, then report it to SCE at 1-800-611-1911.

We understand that Public Safety Power Shutoff events can be disruptive and thank you for your patience as we work to keep your community safe.

This alert applies to the following address:

^address^

Restored No Longer in Scope

Restored & Cancellation (No More Risk Of PSPS)

SMS/TEXT

SCE PSPS Ended: We have restored power for ^address^ and ended the Public Safety Power Shutoff. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage. We know that safety outages are inconvenient and thank you for your patience. View in more languages: www.sce.com/PSPSEnded or view in ASL: <https://ahas.sce.com?id=psps10> To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE PSPS Ended. We have restored power for ^address^ and ended the Public Safety Power Shutoff due to improved weather conditions. If your power is still off, please call 1-800-611-1911 or visit sce dot com slash outage. We understand that safety outages are inconvenient and thank

you for your patience. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff Ended: All Power Restored

From: do_not_reply@scwebsecurities.com

Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

We have restored power and ended the Public Safety Power Shutoff in your area due to improved weather conditions. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage. We understand that safety outages are inconvenient and thank you for your patience.

This alert applies to the following address:

^address^

For more information about PSPS and wildfire safety, please visit sce.com/psps.

Restored in Scope– Risk of PSPS Remains

SMS/TEXT

SCE PSPS Update: Winds have improved enough for us to restore power for ^address^. However, because high winds are still forecast through ^End Day of week^ ^morning/afternoon/evening^ we might have to shut off power again. We will update you as weather conditions change. If your power is still off, please call 1-800-611-1911 or visit sce.com/psps. Thanks for your patience. View in more languages: www.sce.com/PSPSNotAllClear or view in ASL: <https://ahas.sce.com?id=psps11>. To unenroll this phone number from SCE PSPS address alerts, text UNENROLL.

VOICE

SCE PSPS Update. Winds have improved enough for us to restore power for ^address^. However, because high winds are still forecast through ^End Day of week^ ^morning/afternoon/evening^ we may have to shut off your power again. We will keep you updated as weather conditions change. We understand that PSPS outages are inconvenient and thank you for your patience. If your power is still off, please call 1-800-611-1911 or visit sce.com/psps. If you wish to unenroll from PSPS address alerts, press *. To end the call, simply hang up.

EMAIL

Subject: SCE Public Safety Power Shutoff Update: Power restored; PSPS still in effect
From: do_not_reply@scewebservices.com Southern California Edison

For more information on PSPS in your preferred language, click below:

ESPAÑOL

1-800-441-2233

한국어

1-800-628-3061

中文

1-800-843-8343

TIẾNG VIỆT

1-800-327-3031

TAGALOG

1-800-655-4555

MORE LANGUAGES

[View in ASL](#)

Winds have improved enough for us to restore power in your area. However, because high winds are still forecast through **^End Day of week^ ^morning/afternoon/evening^** we may have to shut off your power again. We will keep you updated as weather conditions change. If your power is still off, please call 1-800-611-1911 or visit [sce.com/psps](https://www.sce.com/psps).

We understand that safety outages are inconvenient and thank you for your continued patience.

This alert applies to the following address:

^address^

For more information about PSPS and wildfire safety, please visit [sce.com/psps](https://www.sce.com/psps).

PSPS Notification Cadence

	Notification (SCE Nomenclature)		Advanced Initial	Initial	Update (Alert)	Expected	Shutoff	Continued Shutoff (to be sent the following morning at 7:00)
	CS Notification Template Name		Advanced Initial	Initial	Update	PSPS Expected	PSPS Shutoff	Continued Shutoff
	LNO Notification Template Name		Initial	Update or No Change	Update or No Change	Expected	Shutoff	N/A
	CPUC Nomenclature		Priority Notification	Notification of all affected customers	Notification of all affected customers	1-4 hours in advance of anticipated de-energization	When de-energization is initiated	N/A
	CPUC Required Notification		Y	Y	N	Y	Y	N
Stakeholder			≥ 48 hours before	48 - 24 hours before	48 & 24 hours before	1-4 hours; potential to send out a refresh of the expected notification when exceeds 4 hours ³ .	When De-Energization authorized	N/A
Public Safety Partners	<i>First/Emergency Responders/Public Safety Partners, local governments, and tribes</i>		≥ 48 hours before	48 - 24 hours before	48 & 24 hours before	1-4 hours; potential to send out a refresh of the expected notification when exceeds 4 hours ³ .	When De-Energization authorized	When de-energization continues overnight, sent to customers the next morning
Critical Facilities and Infrastructure			N/A	≥ 24 hours before	24 hours before	1-4 hours; potential to send out a refresh of the expected notification when exceeds 4 hours ³ .	When De-Energization authorized	When de-energization continues overnight, sent to customers the next morning
Customers								

*SCE will target the schedule above to notify customers. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. Naming convention and EONS.

¹ SCE will target the schedule above to notify customers. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. Naming convention

² Cancellation notices apply to circuits that were under PSPS consideration, but not ultimately de-energized. Cancellation notices must be sent within two hours of a decision to remove a circuit from scope and/or cancel an event.

³ Current discussions to update to 1-8 hours; potential to send out a refresh of the expected notification when exceeds 8 hours

⁵ Current discussions to update to Refresh at 6 hours post Expected with operations approval; potential to send out a refresh of the expected notification when exceeds 8 hours

Circuits can be removed from scope by:

(1) Approval of a new MCL; (2) By operations in consultation with meteorology and IC between plan updates; or, (3) Upon cancellation of a PSPS event.

Any of these actions will initiate the two-hour clock requirement. See Regulatory Requirement tab for background email. As of 10.18.2023

SCE needs to send out notifications within 2 hours of the MCL/POC is approved by the IC.

Notification (SCE Nomenclature)		Prep Restore	Restoration Time	Penetration Time Up	Restored In Scope (Restored & In Scope)	Restored No Longer In Scope (Restored & No Longer In Scope)	Cancellation	Public Safety Partner Event Concluded
CS Notification Template Name		Prepare for Restoration	Restoration Time	Penetration Time Up	Restored In Scope	Restored No Longer In Scope	Cancellation	N/A
LNO Notification Template Name		Imminent Restoration	N/A	N/A	Restoration	Restoration	Cancellation	Event Concluded All Clear
CPUC Nomenclature		Immediately before re-energization begins	N/A	N/A	When re-energization is complete	When re-energization is complete	Cancellation Notification ²	Cancellation Notification ²
CPUC Required Notification		Y	N	N	Y	Y	Y	N
Stakeholder								
	First/Emergency Responders/Public Safety Partners, local governments, and tribes	When restoration patrols begin	N/A	N/A	When circuit is temporarily restored but still in scope for PSPS (usually when there is a break in POC)	When circuits were de-energized and have been restored and are no longer in scope	Upon cancellation of a PSPS event, or Removal from scope. Circuit has not been de-energized	Sent to Public Safety Partners at the conclusion of PSPS event.
Public Safety Partners					When circuit is temporarily restored but still in scope for PSPS (usually when there is a break in POC)	When circuits were de-energized and have been restored and are no longer in scope or When circuits previously received Restored In Scope	Upon cancellation of a PSPS event, or Removal from scope. Circuit has not been de-energized	Upon cancellation of a PSPS event, or Removal from scope. Circuit has not been de-energized
Critical Facilities and Infrastructure		When restoration patrols begin	Customer is de-energized and estimated restoration time is pending inspection results.	Restoration exceeds 8 hours or updated timing for customers who received	When circuit is temporarily restored but still in scope for PSPS (usually when there is a break in POC)	When circuits were de-energized and have been restored and are no longer in scope or When circuits previously received Restored In Scope	Upon cancellation of a PSPS event, or Removal from scope. Circuit has not been de-energized	Sent to Public Safety Partners at the conclusion of PSPS event.
Customers		When restoration patrols begin	Customer is de-energized and estimated restoration time is pending inspection results.	Restoration exceeds 8 hours or updated timing for customers who received	When circuit is temporarily restored but still in scope for PSPS (usually when there is a break in POC)	When circuits were de-energized and have been restored and are no longer in scope or When circuits previously received Restored In Scope	Upon cancellation of a PSPS event, or Removal from scope. Circuit has not been de-energized	Sent to Public Safety Partners at the conclusion of PSPS event.

¹SCE will target the schedule above to notify customers. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. Naming convention and EONS.

²SCE will target the schedule above to notify customers. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. Naming convention

³Cancellation notices apply to circuits that were under PSPS consideration, but not ultimately de-energized. Cancellation notices must be sent within two hours of a decision to remove a circuit from scope and/or cancel an event.

⁴Current discussions to update to 1-8 hours, potential to send out a refresh of the expected notification when exceeds 8 hours

⁵Current discussions to update to Refresh at 6 hours post Expected with operations approval; potential to send out a refresh of the expected notification when exceeds 8 hours

Circuits can be removed from scope by:

(1) Approval of a new MCL; (2) By operations in consultation with meteorology and IC between plan updates; or, (3) Upon cancellation of a PSPS event.

Any of these actions will initiate the two-hour clock requirement. See Regulatory Requirement tab for background email. As of 10.18.2023

SCE needs to send out notifications within 2 hours of the MCL/POC is approved by the IC.

Appendix D
PSPS Exercises
July 1, 2026

This appendix will be filed via mixed media with Commission's Docket office and can be accessed at: <https://on.sce.com/PSPSPreSeasonReporting>

Appendix E

Education and Outreach

July 1, 2026

This appendix will be filed via mixed media with Commission's Docket office and can be accessed at: <https://on.sce.com/PSPSPreSeasonReporting>

Appendix F

PSPS Pre-Season Tables

July 1, 2026

This appendix will be filed via mixed media with Commission's Docket office and can be accessed at: <https://on.sce.com/PSPSPreSeasonReporting>