

Searles Valley Minerals Inc. (Permittee)
Searles Domestic Water Company LLC (A Wholly Owned Subsidiary)
2020 Consumer Confidence Report

June 28, 2020

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water – All water delivered by the Searles Domestic Water Company (SDWC) to its customers is produced from five Searles Valley Minerals (SVM) owned wells which draw water from the Indian Wells Valley groundwater basin. The water produced by SVM’s five wells is transported through two 29-mile pipelines and then merges into one system for controlled flow into a water treatment plant. The treated potable water leaving the treatment plant is distributed through SVM pipelines throughout Searles Valley. A portion of this treated potable water is sold to SDWC for domestic use. SDWC accesses water directly from the SVM pipeline system at numerous connection points and then meters it into the SDWC distribution system as fully treated and chlorinated domestic water. In 2020 SDWC purchased 61 million gallons of water for domestic use.

Source Water Assessment – The State Water Resources Control Board (State Board) conducts Source Water Assessments for all drinking water sources across the state. The Source Water Assessment for the five SVM owned wells was conducted in 2002.

Groundwater sources in this system are considered most vulnerable to the following activities not associated with detected contaminants: automobile repair and body shops, gas stations, funeral services/graveyards, hotels/motels, schools, transportation corridors, automobile car washes, junk/scrap/salvage yards, injection wells/dry wells, sumps, sand/gravel mining. Groundwater sources in this system are considered most vulnerable to the following activities associated with contaminants detected in the water supply: high density housing, parks, and high density septic systems.

A copy of the complete assessment may be viewed at the **State Board San Bernardino District Office, Government Center 4th Floor, 464 West Fourth St. Suite 437, San Bernardino, CA 92401**. You may request a summary be sent to you by contacting the **State Board San Bernardino District Office (909) 383-4320**. For more details contact Audrey Schuyler at **(760) 372-5326**.

TERMS USED IN THIS REPORT¹:

“Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.” Levels above the MCL do not mean adverse health consequences will result from consumption of the water.

“Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).” Levels above the MCLG do not mean adverse health consequences will result from consumption of the water.

“Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.” Levels above the PHGs do not mean adverse health consequences will result from consumption of the water.

“Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.” Levels above the MRDL do not mean adverse health consequences will result from consumption of the water.

“Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.” Levels above the MRDLG do not mean adverse health consequences will result from consumption of the water.

“Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.” Levels above the PDWS do not mean adverse health consequences will result from consumption of the water.

“Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.” Levels above the SDWS do not mean adverse health consequences will result from consumption of the water.

“Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.”

“Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.” Levels above the AL do not mean adverse health consequences will result from consumption of the water.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

¹ SDWC is required by regulation to use certain terms defined at California Code of Regulations, Title 22, Section 64481, and denotes the use of those terms with quotation marks.

California Code of Regulations, Title 22, Section 64481 further provides: “The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.”

“Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.”

“In order to ensure that tap water is safe to drink, the USEPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.”

The following tables list all of the drinking water substances that were detected during the most recent sampling for the constituent. The presence of these substances in the water does not necessarily indicate that the water poses a health risk. If you have a concern about the safety of your water, you should discuss it with your health professional and/or the USEPA or State Board officials. The State Board allows us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any exceedance of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the exceedance is provided later in this report.

DETECTION OF UNREGULATED SUBSTANCES					
Substances (Units)	Sample Date	Average Detected	Range of Detections	MCL	PHG
Boron (ppb)	2020	996	210 - 1900*	NA	NA
Chromium VI (ppb)	2020	.72	ND – 3.6	NA	.02
Hardness (ppm)	2020	93.8	4.6 - 340	NA	NA
pH (units)	2020	8.68	7.9 – 9.4	NA	NA
Potassium (ppm)	2020	2.32	ND – 7.7	NA	NA
Sodium (ppm)	2020	115.6	36 - 220	NA	NA
Vanadium (ppb)	2020	16.02	8.1 – 23.0	NA	NA

*Westend Wells 2 and 4, and IW Well 35 detected Boron concentrations of 1,900, 1,300, and 1,000 ppb respectively in 2020.

DETECTION OF SUBSTANCES WITH A <u>PRIMARY</u> DRINKING WATER STANDARD						
Substance (Units)	Sample Date	Average Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	“Typical Source of Contaminant” ²
Arsenic (ppb)	2020	1.53	ND – 5.5	10	.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	2020	0.024	ND - .120	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2020	.83	.32 – 1.4	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	2020	1.9	ND – 5.7	15	(0)	Erosion of natural deposits
Halo Acetic Acids (ppb)	2020	4.8	4.8	60	NA	Byproduct of drinking water disinfection
Nitrate as N (NO3-N) (ppm)	2020	1.17	ND – 2.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrite as N (NO2-N) (ppm)	2020	.11	ND - .55	1	1	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
TTHM’s (Total Trihalomethanes) (ppb)	2020	19.9	19.9	80	NA	By-product of drinking water disinfection
Uranium (pCi/L)	2020	1.72	ND – 4.4	20	0.43	Erosion of natural deposits

*Any exceedance of an MCL, MRDL, or TT is asterisked. Additional information regarding the exceedance is provided later in this report.

DETECTION OF SUBSTANCES WITH A <u>SECONDARY</u> DRINKING WATER STANDARD					
Substance (Units)	Sample Date	Average Detected	Range of Detections	MCL	“Typical Source of Contaminant” ³
Chloride (ppm)	2020	137.26	9.3 - 500	500	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	2020	5.63	ND – 190	300	Runoff/leaching from natural deposits; industrial wastes
Sulfate (ppm)	2020	34.8	9 - 80	500	Runoff/leaching from natural deposits; industrial wastes
Odor - Threshold (units)	2020	1	1	3	Naturally-occurring organic materials
Specific Conductance (umhos)	2020	741	280 – 1900*	1600	Substances that form ions when in water; seawater influence
Turbidity (NTU)	2020	.42	ND – 1.3	TT	Soil runoff
Total Dissolved Solids (TDS) (ppm)	2020	450	200 - 1200*	1000	Runoff/leaching from natural deposits

*Any exceedance of an MCL, MRDL, or TT is asterisked. Additional information regarding the exceedance is provided later in this report.

² As noted above, the potential sources for many substances are numerous, so this list is not comprehensive. This list is quoted from California Code of Regulations, Title 22, Appendix 64481-A.

³ As noted above, the potential sources for many substances are numerous, so this list is not comprehensive. This list is quoted from California Code of Regulations, Title 22, Appendix 64481-B.

TAP WATER SAMPLES – LEAD AND COPPER								
Substance (Units)	Sample Date	No of Samples Collected	90 TH Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	“Typical Source of Contaminant” ⁴
Lead (ppb)	2018	10	No	0	15	0.2	Two	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2018	10	No	0	1.3	0.3	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Tap water samples were collected for lead and copper analyses from sample sites throughout the community.

Additional General Information on Drinking Water

California Code of Regulation, Title 22, Section 66481 also provides that “Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).”

Lead and Drinking Water: In 1991 the U.S. Environmental Protection Agency (USEPA) set final regulations for lead and copper in drinking water. This regulation requires analyzing home tap water samples instead of analyzing the water before it enters the distribution system. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is believed to be primarily from materials and components associated with service lines and home plumbing. SDWC is responsible for providing high quality drinking water but cannot control the variety of materials used in household plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Substances Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement

Well #2 MCL Exceedances: The following substances at Well #2 were detected at levels which exceed the secondary MCL’s: **Specific Conductivity** is consistently higher than the secondary MCL of 1600 umhos; **Total Dissolved Solids** are consistently higher than the secondary MCL of 1000 ppm. After blending Well #2 water with water from the other four wells into one continuous merged flow that feeds the water treatment plant, the measured average detection level is below the limit set for secondary MCL. Secondary MCL’s are set relative to aesthetic effects (e.g., color, taste and odor). If you are concerned about

⁴ As noted above, the potential sources for many substances are numerous, so this list is not comprehensive. This list is quoted from California Code of Regulations, Title 22, Appendix 64481-A and 64481-B.

any of these exceedances in your water, you may wish to have your water tested and/or talk to your health care professional. Information on these substances in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater>.

Additional General Information

Water Treatment: Groundwater is naturally low in bacteria substances, but a minimum amount of sodium hypochlorite is added to keep the distribution system disinfected and for taste and odor control.

Water Conservation: Did you know that the average U.S. household uses 350 gallons of water per day? Here are some handy tips to conserve water:

- End wasteful outdoor water activities
- Fix water leaks
- Replace older toilets with high-efficiency models
- Be water wise with clothes washers and dishwashers
- Make your showerheads and faucets water efficient.

Water Costs Money...don't waste it! A dripping faucet can waste 3 gallons a day...a total of 1,095 gallons a year. Teach your kids about water conservation to ensure a future generation that uses water wisely.

Customer Service: The SDWC receives numerous inquiries from customers. Our goal is to provide the highest possible level of service in responding to these inquiries. Our experienced and knowledgeable staff, which includes one Grade III Water Distribution Operator and one Grade I Water Distribution Operator, can provide answers to most questions over the telephone. Specific problems may require a visit to the customer's home or business, collection and testing of water samples, and other investigative actions. Whatever the situation, all inquiries are handled as quickly and thoroughly as possible.

Contact Information: We hope this report furthers your understanding of the quality of the SDWC's water supply. For answers to water quality questions and for additional water quality data, contact Audrey Schuyler (manager) or Kenneth (Tony) Helton (master water technician) at (760) 372-5326.