

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>
Sent: Sunday, October 27, 2019 8:46:42 PM
To: usrb@cpuc.ca.gov <usrb@cpuc.ca.gov>
Cc: Allen, Meredith <MEAe@pge.com>
Subject: Electric Safety Incident Reported- PG&E Incident No: 191027-9396

*******CAUTION: This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.*******

The Following information regarding this incident has been reported:

Reporting Date: 10/27/2019 8:16:15 PM
Incident Date: 10/27/2019 @ 2:30 p.m.
Reported By: Meredith Allen, Sr. Director
Utility Name: PG&E
Phone Number: (415)828-5768
Email Address: MEAe@pge.com

Incident Location: Camino Diablo Rd Lafayette, Contra Costa

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Rossmoor 1104
- Voltage (KV): 12
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - ____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: At approximately 1750 hours on October 27, 2019, a PG&E Troubleman responded to reports of trouble on Camino Diablo road in Lafayette near the location of a fire. At the location, the Troubleman observed a fallen pole and transformer. Contra Costa Fire Department personnel on site communicated to the Troubleman that they were looking at the transformer as a potential ignition source. The incident location is not in Tier 3, Tier 2, or Tier 1 High Hazard Zone High Fire Threat District. PG&E is reporting this incident under the Media Criterion. This information is preliminary.